

Statement of Basis of the Federal Operating Permit

Blue Cube Operations LLC

Site Name: EDC-VCM
Physical Location: 2301 N Brazosport Blvd
Nearest City: Freeport
County: Brazoria

Permit Number: O2204
Project Type: Minor Revision

The North American Industry Classification System (NAICS) Code: 32519
NAICS Name: Other Basic Organic Chemical Manufacturing

This Statement of Basis sets forth the legal and factual basis for the draft changes to the permit conditions resulting from the minor revision project in accordance with 30 TAC §122.201(a)(4). The applicant has submitted an application for a minor permit revision per §§ 122.215-217. This document may include the following information:

- A description of the facility/area process description;
- A description of the revision project;
- A basis for applying permit shields;
- A list of the federal regulatory applicability determinations;
- A table listing the determination of applicable requirements;
- A list of the New Source Review Requirements;
- The rationale for periodic monitoring methods selected;
- The rationale for compliance assurance methods selected;
- A compliance status; and
- A list of available unit attribute forms.

Prepared on: April 4, 2024

Operating Permit Basis of Determination

Description of Revisions

Following changes are made during this revision.

- (1) New applicable requirements are determined for following:
 - a. Unit IDs OC5U5B01 and OC5U5B02: The attribute values for these units are updated and new applicable requirements for 40 CFR Part 60 Subpart Dc are determined and 40 CFR Part 60, Subpart Db requirements are removed.
 - b. Unit IDs OC5U5T498 and OC5U5D497 – 40 CFR Part 63, Subpart GGGGG
 - c. Unit ID OC5U5FU7B (OP-UA12) – 40 CFR Part 63, Subpart EEEE, 30 TAC Chapter 115, Pet. Refinery & Petrochemicals, and 40 CFR Part 60, Subpart VV
- (2) Originally, the applicant submitted a revised compliance schedule. But ultimately Blue Cube contacted Enforcement Division with the new information and was finally able to resolve this issue. The Compliance Schedule and the associated term and condition is removed.
- (3) NSR permit 120549 with new effective issuance date of June 20, 2023, is incorporated.
- (4) The Unit ID OC5U5FU7 is changed to OC5U5FU7A.
- (5) For OC5U5FU7A and OC5U5FU7B, the Unit ID descriptions are changed.
- (6) The Pre-Construction Authorization for following Unit ID is updated: OC5U5FU7A.
- (7) Updated PBR Supplemental Tables dated November 13, 2023, are incorporated in Special Term and Condition No. 20.

Permit Area Process Description

Ethylene Di-chloride (EDC) is produced by direct chlorination. This process involves reacting chlorine and ethylene in a boiling bed reactor in the presence of iron. The gas chlorine is supplied via pipeline from the liquefaction plant. Ethylene is supplied via pipeline from the light carbon plant.

Solids and heavies in the reactor bed are flow controlled for heavies removal and isolation of solids. EDC overheads from heavies distillation are recycled back to the reactor while bottoms are filtered and stored in light heavies byproduct tanks. Light materials separated from EDC are fed to a refrigerated exchanger and stored for feed to the lights recovery unit. There, acid is reacted out by adding cell effluent. The resulting EDC/ethyl chloride mixture is transferred via pipeline to another plant and recovered.

Vents from the EDC process are transferred to Unit V. In the event there is a problem at Unit V, these vents can be sent through the scrubber system and on to the flare.

In the reactor, EDC is produced along with byproducts. The process section contains reactors, heat removal equipment, condensers, distillation columns, pumps and related equipment. Process vents are sent to Halogen Acid Furnaces (HAF).

The oxy-chlorination section reacts oxygen, ethylene, and anhydrous hydrogen chloride (HCl) to form primarily ethylene dichloride. Water, carbon dioxide, carbon monoxide and trace quantities of other chlorinated hydrocarbons (RCL) are the byproducts. These RCLs are collected and sent to the HAF for further processing. Process vents are sent to the thermal oxidizing (THROX) unit. Ethylene dichloride produced is forwarded to the EDC drying section.

EDC drying section removes water and lower boiling components by distillation from the EDC produced in the oxy-chlorination section. Dry EDC from this section forwards to the EDC finishing section. The EDC finished section purifies EDC by distillation from the EDC cracking furnace section and removes both higher and lower boiling RCLs. The equipment consists of distillation towers, pumps, heat exchangers and related equipment. Purified EDC is stored and then fed to cracking furnaces.

The furnaces thermally crack finished EDC to Vinyl Chloride Monomer (VCM) and Hydrogen Chloride (HCl). The heat source for this reaction is the controlled combustion of fuel grade methane. Any vents and liquid wastes are sent to HAF units.

The HAF units and THROX units are used to incinerate organic waste streams, process vents and liquids from other sections of the plants. These streams are fed to the combustion devices along with necessary supplementary fuel, air and steam. The effluent gases from the units are water quenched and aqueous HCl is recovered by using scrubbers and wash tower.

Purified VCM is pumped from the finishing section to one of the four pressurized storage spheres, or it can be directly pumped to pipeline to customers.

FOPs at Site

The “application area” consists of the emission units and that portion of the site included in the application and this permit. Multiple FOPs may be issued to a site in accordance with 30 TAC § 122.201(e). When there is only one area for the site, then the application information and permit will include all units at the site. Additional FOPs that exist at the site, if any, are listed below.

Additional FOPs: O1388, O2202, O2207, O2208, O2214

Major Source Pollutants

The table below specifies the pollutants for which the site is a major source:

Major Pollutants	VOC, PM, NOX, HAPS, CO
------------------	------------------------

Reading State of Texas’s Federal Operating Permit

The Title V Federal Operating Permit (FOP) lists all state and federal air emission regulations and New Source Review (NSR) authorizations (collectively known as “applicable requirements”) that apply at a particular site or permit area (in the event a site has multiple FOPs). **The FOP does not authorize new emissions or new construction activities.** The FOP begins with an introductory page which is common to all Title V permits. This page gives the details of the company, states the authority of the issuing agency, requires the company to operate in accordance with this permit and 30 Texas Administrative Code (TAC) Chapter 122, requires adherence with NSR requirements of 30 TAC Chapter 116, and finally indicates the permit number and the issuance date.

This is followed by the table of contents, which is generally composed of the following elements. Not all permits will have all of the elements.

- General Terms and Conditions
- Special Terms and Conditions
 - Emissions Limitations and Standards, Monitoring and Testing, and Recordkeeping and Reporting
 - Additional Monitoring Requirements
 - New Source Review Authorization Requirements
 - Compliance Requirements
 - Protection of Stratosphere Ozone
 - Permit Location
 - Permit Shield (30 TAC § 122.148)
- Attachments
 - Applicable Requirements Summary
 - Unit Summary
 - Applicable Requirements Summary
 - Additional Monitoring Requirements
 - Permit Shield
 - New Source Review Authorization References
 - Compliance Plan
 - Alternative Requirements
- Appendix A
 - Acronym list

General Terms and Conditions

The General Terms and Conditions are the same and appear in all permits. The first paragraph lists the specific citations for 30 TAC Chapter 122 requirements that apply to all Title V permit holders. The second paragraph describes the requirements for record retention. The third paragraph provides details for voiding the permit, if applicable. The fourth paragraph states that the permit holder shall comply with the requirements of 30 TAC Chapter 116 by obtaining a New

Source Review authorization prior to new construction or modification of emission units located in the area covered by this permit. The fifth paragraph provides details on submission of reports required by the permit.

Special Terms and Conditions

Emissions Limitations and Standards, Monitoring and Testing, and Recordkeeping and Reporting. The TCEQ has designated certain applicable requirements as site-wide requirements. A site-wide requirement is a requirement that applies uniformly to all the units or activities at the site. Units with only site-wide requirements are addressed on Form OP-REQ1 and are not required to be listed separately on an OP-UA Form or Form OP-SUM. Form OP-SUM must list all units addressed in the application and provide identifying information, applicable OP-UA Forms, and preconstruction authorizations. The various OP-UA Forms provide the characteristics of each unit from which applicable requirements are established. Some exceptions exist as a few units may have both site-wide requirements and unit specific requirements.

Other conditions. The other entries under special terms and conditions are in general terms referring to compliance with the more detailed data listed in the attachments.

Attachments

Applicable Requirements Summary. The first attachment, the Applicable Requirements Summary, has two tables, addressing unit specific requirements. The first table, the Unit Summary, includes a list of units with applicable requirements, the unit type, the applicable regulation, and the requirement driver. The intent of the requirement driver is to inform the reader that a given unit may have several different operating scenarios and the differences between those operating scenarios.

The applicable requirements summary table provides the detailed citations of the rules that apply to the various units. For each unit and operating scenario, there is an added modifier called the "index number," detailed citations specifying monitoring and testing requirements, recordkeeping requirements, and reporting requirements. The data for this table is based on data supplied by the applicant on the OP-SUM and various OP-UA forms.

Additional Monitoring Requirement. The next attachment includes additional monitoring the applicant must perform to ensure compliance with the applicable standard. Compliance assurance monitoring (CAM) is often required to provide a reasonable assurance of compliance with applicable emission limitations/standards for large emission units that use control devices to achieve compliance with applicant requirements. When necessary, periodic monitoring (PM) requirements are specified for certain parameters (i.e. feed rates, flow rates, temperature, fuel type and consumption, etc.) to determine if a term and condition or emission unit is operating within specified limits to control emissions. These additional monitoring approaches may be required for two reasons. First, the applicable rules do not adequately specify monitoring requirements (exception- Maximum Achievable Control Technology Standards (MACTs) generally have sufficient monitoring), and second, monitoring may be required to fill gaps in the monitoring requirements of certain applicable requirements. In situations where the NSR permit is the applicable requirement requiring extra monitoring for a specific emission unit, the preferred solution is to have the monitoring requirements in the NSR permit updated so that all NSR requirements are consolidated in the NSR permit.

Permit Shield. A permit may or may not have a permit shield, depending on whether an applicant has applied for, and justified the granting of, a permit shield. A permit shield is a special condition included in the permit document stating that compliance with the conditions of the permit shall be deemed compliance with the specified potentially applicable requirement(s) or specified applicable state-only requirement(s).

New Source Review Authorization References. All activities which are related to emissions in the state of Texas must have a NSR authorization prior to beginning construction. This section lists all units in the permit and the NSR authorization that allowed the unit to be constructed or modified. Units that do not have unit specific applicable requirements other than the NSR authorization do not need to be listed in this attachment. While NSR permits are not physically a part of the Title V permit, they are legally incorporated into the Title V permit by reference. Those NSR permits whose emissions exceed certain PSD/NA thresholds must also undergo a Federal review of federally regulated pollutants in addition to review for state regulated pollutants.

Compliance Plan. A permit may have a compliance schedule attachment for listing corrective actions plans for any emission unit that is out of compliance with an applicable requirement.

Alternative Requirements. This attachment will list any alternative monitoring plans or alternative means of compliance for applicable requirements that have been approved by the EPA Administrator and/or the TCEQ Executive Director.

Acronym list. This attachment lists the common acronyms used when discussing the FOPs.

Stationary vents subject to 30 TAC Chapter 111, Subchapter A, § 111.111(a)(1)(B) addressed in the Special Terms and Conditions

The site contains stationary vents with a flowrate less than 100,000 actual cubic feet per minute (acfm) which are limited, over a six-minute average, to 20% opacity as required by 30 TAC § 111.111(a)(1)(B). As a site may have a large number of stationary vents that fall into this category, they are not required to be listed individually in the permit's Applicable Requirements Summary. This is consistent with EPA's White Paper for Streamlined Development of Part 70 Permit Applications, July 10, 1995, that states that requirements that apply identically to emission units at a site can be treated on a generic basis such as source-wide opacity limits.

Periodic monitoring is specified in Special Term and Condition 3 for stationary vents subject to 30 TAC § 111.111(a)(1)(B) to verify compliance with the 20% opacity limit. These vents are not expected to produce visible emissions during normal operation. The TCEQ evaluated the probability of these sources violating the opacity standards and determined that there is a very low potential that an opacity standard would be exceeded. It was determined that continuous monitoring for these sources is not warranted as there would be very limited environmental benefit in continuously monitoring sources that have a low potential to produce visible emissions. Therefore, the TCEQ set the visible observation monitoring frequency for these sources to once per calendar quarter.

The TCEQ has exempted vents that are not capable of producing visible emissions from periodic monitoring requirements. These vents include sources of colorless VOCs, non-fuming liquids, and other materials that cannot produce emissions that obstruct the transmission of light. Passive ventilation vents, such as plumbing vents, are also included in this category. Since this category of vents are not capable of producing opacity due to the physical or chemical characteristics of the emission source, periodic monitoring is not required as it would not yield any additional data to assure compliance with the 20% opacity standard of 30 TAC § 111.111(a)(1)(B).

In the event that visible emissions are detected, either through the quarterly observation or other credible evidence, such as observations from company personnel, the permit holder shall either report a deviation or perform a Test Method 9 observation to determine the opacity consistent with the 6-minute averaging time specified in 30 TAC § 111.111(a)(1)(B). An additional provision is included to monitor combustion sources more frequently than quarterly if alternate fuels are burned for periods greater than 24 consecutive hours. This will address possible emissions that may arise when switching fuel types.

The applicant opted to comply with the more stringent 20% opacity standard under 30 TAC § 111.111(a)(1)(B) for all stationary vents that are subject to the 30% opacity standard under 30 TAC § 111.111(a)(1)(A).

Stationary Vents subject to 30 TAC Chapter 111 not addressed in the Special Terms and Conditions

All other stationary vents subject to 30 TAC Chapter 111 not covered in the Special Terms and Conditions are listed in the permit's Applicable Requirements Summary. The basis for the applicability determinations for these vents are listed in the Determination of Applicable Requirements table.

Federal Regulatory Applicability Determinations

The following chart summarizes the applicability of the principal air pollution regulatory programs to the permit area:

Regulatory Program	Applicability (Yes/No)
Prevention of Significant Deterioration (PSD)	No
Nonattainment New Source Review (NNSR)	No
Minor NSR	Yes

Regulatory Program	Applicability (Yes/No)
40 CFR Part 60 - New Source Performance Standards	Yes
40 CFR Part 61 - National Emission Standards for Hazardous Air Pollutants (NESHAPs)	Yes
40 CFR Part 63 - NESHAPs for Source Categories	Yes
Title IV (Acid Rain) of the Clean Air Act (CAA)	No
Title V (Federal Operating Permits) of the CAA	Yes
Title VI (Stratospheric Ozone Protection) of the CAA	Yes
CSAPR (Cross-State Air Pollution Rule)	No
Federal Implementation Plan for Regional Haze (Texas SO ₂ Trading Program)	No

Basis for Applying Permit Shields

An operating permit applicant has the opportunity to specifically request a permit shield to document that specific applicable requirements do not apply to emission units in the permit. A permit shield is a special condition stating that compliance with the conditions of the permit shall be deemed compliance with the specified potentially applicable requirements or specified potentially applicable state-only requirements. A permit shield has been requested in the application for specific emission units. For the permit shield requests that have been approved, the basis of determination for regulations that the owner/operator need not comply with are located in the "Permit Shield" attachment of the permit.

Insignificant Activities and Emission Units

In general, units not meeting the criteria for inclusion on either Form OP-SUM or Form OP-REQ1 are not required to be addressed in the operating permit application. Examples of these types of units include, but are not limited to, the following:

De Minimis Sources

1. Sources identified in the "De Minimis Facilities or Sources" list maintained by TCEQ. The list is available at https://www.tceq.texas.gov/permitting/air/newsourcereview/de_minimis.html.

Miscellaneous Sources

2. Office activities such as photocopying, blueprint copying, and photographic processes.
3. Outdoor barbecue pits, campfires, and fireplaces.
4. Storage and handling of sealed portable containers, cylinders, or sealed drums.
5. Vehicle exhaust from maintenance or repair shops.
6. Storage and use of non-VOC products or equipment for maintaining motor vehicles operated at the site (including but not limited to, antifreeze and fuel additives).
7. Air contaminant detectors and recorders, combustion controllers and shut-off devices, product analyzers, laboratory analyzers, continuous emissions monitors, other analyzers and monitors, and emissions associated with sampling activities. Exception to this category includes sampling activities that are deemed fugitive emissions and under a regulatory leak detection and repair program.
8. Steam vents, steam leaks, and steam safety relief valves, provided the steam (or boiler feedwater) has not contacted other materials or fluids containing regulated air pollutants other than boiler water treatment chemicals.
9. Storage of water that has not contacted other materials or fluids containing regulated air pollutants other than boiler water treatment chemicals.

10. Well cellars.
11. Fire or emergency response equipment and training, including but not limited to, use of fire control equipment including equipment testing and training, and open burning of materials or fuels associated with firefighting training.
12. Equipment used exclusively for the melting or application of wax.
13. Instrument systems utilizing air, natural gas, nitrogen, oxygen, carbon dioxide, helium, neon, argon, krypton, and xenon.
14. Battery recharging areas.

Sources Authorized by 30 TAC Chapter 106, Permits by Rule

15. Sources authorized by §106.102: Combustion units designed and used exclusively for comfort heating purposes employing liquid petroleum gas, natural gas, solid wood, or distillate fuel oil.
16. Sources authorized by §106.122: Bench scale laboratory equipment and laboratory equipment used exclusively for chemical and physical analysis, including but not limited to, assorted vacuum producing devices and laboratory fume hoods.
17. Sources authorized by §106.141: Batch mixers with rated capacity of 27 cubic feet or less for mixing cement, sand, aggregate, lime, gypsum, additives, and/or water to produce concrete, grout, stucco, mortar, or other similar products.
18. Sources authorized by §106.143: Wet sand and gravel production facilities that obtain material from subterranean and subaqueous beds where the deposits of sand and gravel are consolidated granular materials resulting from natural disintegration of rock and stone and have a production rate of 500 tons per hour or less.
19. Sources authorized by §106.148: Railcar or truck unloading of wet sand, gravel, aggregate, coal, lignite, and scrap iron or scrap steel (but not including metal ores, metal oxides, battery parts, or fine dry materials) into trucks or other railcars for transportation to other locations.
20. Sources authorized by §106.149: Sand and gravel production facilities that obtain material from deposits of sand and gravel consisting of natural disintegration of rock and stone, provided that crushing or breaking operations are not used and no blasting is conducted to obtain the material.
21. Sources authorized by §106.161: Animal feeding operations which confine animals in numbers specified and any associated on-site feed handling and/or feed millings operations, not including caged laying and caged pullet operations.
22. Sources authorized by §106.162: Livestock auction sales facilities.
23. Sources authorized by §106.163: All animal racing facilities, domestic animal shelters, zoos, and their associated confinement areas, stables, feeding areas, and waste collection and treatment facilities, other than incineration units.
24. Sources authorized by §106.229: Equipment used exclusively for the dyeing or stripping of textiles.
25. Sources authorized by §106.241: Any facility where animals or poultry are slaughtered and prepared for human consumption provided that waste products such as blood, offal, and feathers are stored in such a manner as to prevent the creation of a nuisance condition and these waste products are removed from the premises daily or stored under refrigeration.
26. Sources authorized by §106.242: Equipment used in eating establishments for the purpose of preparing food for human consumption.
27. Sources authorized by §106.243: Smokehouses in which the maximum horizontal inside cross-sectional area does not exceed 100 square feet.
28. Sources authorized by §106.244: Ovens, mixers, blenders, barbecue pits, and cookers if the products are edible and intended for human consumption.
29. Sources authorized by §106.266: Vacuum cleaning systems used exclusively for industrial, commercial, or residential housekeeping purposes.
30. Sources authorized by §106.301: Aqueous fertilizer storage tanks.
31. Sources authorized by §106.313: All closed tumblers used for the cleaning or deburring of metal products without abrasive blasting, and all open tumblers with a batch capacity of 1,000 lbs. or less.
32. Sources authorized by §106.316: Equipment used for inspection of metal products.
33. Sources authorized by §106.317: Equipment used exclusively for rolling, forging, pressing, drawing, spinning, or extruding either hot or cold metals by some mechanical means.
34. Sources authorized by §106.318: Die casting machines.
35. Sources authorized by §106.319: Foundry sand mold forming equipment to which no heat is applied.
36. Sources authorized by §106.331: Equipment used exclusively to package pharmaceuticals and cosmetics or to coat pharmaceutical tablets.
37. Sources authorized by §106.333: Equipment used exclusively for the mixing and blending of materials at ambient temperature to make water-based adhesives.

38. Sources authorized by §106.372: Any air separation or other industrial gas production, storage, or packaging facility. Industrial gases, for purposes of this list, include only oxygen, nitrogen, helium, neon, argon, krypton, and xenon.
39. Sources authorized by §106.391: Presses used for the curing of rubber products and plastic products.
40. Sources authorized by §106.394: Equipment used for compression molding and injection molding of plastics.
41. Sources authorized by §106.414: Equipment used exclusively for the packaging of lubricants or greases.
42. Sources authorized by §106.415: Laundry dryers, extractors, and tumblers used for fabrics cleaned with water solutions of bleach or detergents.
43. Sources authorized by §106.431: Equipment used exclusively to mill or grind coatings and molding compounds where all materials charged are in paste form.
44. Sources authorized by §106.432: Containers, reservoirs, or tanks used exclusively for dipping operations for coating objects with oils, waxes, or greases where no organic solvents, diluents, or thinners are used; or dipping operations for applying coatings of natural or synthetic resins which contain no organic solvents.
45. Sources authorized by §106.451: Blast cleaning equipment using a suspension of abrasives in water.
46. Sources authorized by §106.453: Equipment used for washing or drying products fabricated from metal or glass, provided no volatile organic materials are used in the process and no oil or solid fuel is burned.
47. Sources authorized by §106.471: Equipment used exclusively to store or hold dry natural gas.
48. Sources authorized by §106.531: Sewage treatment facilities, excluding combustion or incineration equipment, land farms, or grease trap waste handling or treatment facilities.

Determination of Applicable Requirements

The tables below include the applicability determinations for the emission units, the index number(s) where applicable, and all relevant unit attribute information used to form the basis of the applicability determination. The unit attribute information is a description of the physical properties of an emission unit which is used to determine the requirements to which the permit holder must comply. For more information about the descriptions of the unit attributes specific Unit Attribute Forms may be viewed at www.tceq.texas.gov/permitting/air/nav/air_all_ua_forms.html.

A list of unit attribute forms is included at the end of this document. Some examples of unit attributes include construction date; product stored in a tank; boiler fuel type; etc.. Generally, multiple attributes are needed to determine the requirements for a given emission unit and index number. The table below lists these attributes in the column entitled "Basis of Determination." Attributes that demonstrate that an applicable requirement applies will be the factual basis for the specific citations in an applicable requirement that apply to a unit for that index number. The TCEQ Air Permits Division has developed flowcharts for determining applicability of state and federal regulations based on the unit attribute information in a Decision Support System (DSS). These flowcharts can be accessed via the internet at www.tceq.texas.gov/permitting/air/nav/air_supportsys.html. The Air Permits Division staff may also be contacted for assistance at (512) 239-1250.

The attributes for each unit and corresponding index number provide the basis for determining the specific legal citations in an applicable requirement that apply, including emission limitations or standards, monitoring, recordkeeping, and reporting. The rules were found to apply or not apply by using the unit attributes as answers to decision questions found in the flowcharts of the DSS. Some additional attributes indicate which legal citations of a rule apply. The legal citations that apply to each emission unit may be found in the Applicable Requirements Summary table of the draft permit. There may be some entries or rows of units and rules not found in the permit, or if the permit contains a permit shield, repeated in the permit shield area. These are sets of attributes that describe negative applicability, or; in other words, the reason why a potentially applicable requirement does not apply.

If applicability determinations have been made which differ from the available flowcharts, an explanation of the decisions involved in the applicability determination is specified in the column "Changes and Exceptions to RRT." If there were no exceptions to the DSS, then this column has been removed.

The draft permit includes all emission limitations or standards, monitoring, recordkeeping and reporting required by each applicable requirement. If an applicable requirement does not require monitoring, recordkeeping, or reporting, the word "None" will appear in the Applicable Requirements Summary table. If additional periodic monitoring is required for an applicable requirement, it will be explained in detail in the portion of this document entitled "Rationale for Compliance Assurance Monitoring (CAM)/ Periodic Monitoring Methods Selected."

When attributes demonstrate that a unit is not subject to an applicable requirement, the applicant may request a permit shield for those items. The portion of this document entitled "Basis for Applying Permit Shields" specifies which units, if any, have a permit shield.

Operational Flexibility

When an emission unit has multiple operating scenarios, it will have a different index number associated with each operating condition. This means that units are permitted to operate under multiple operating conditions. The applicable requirements for each operating condition are determined by a unique set of unit attributes. For example, a tank may store two different products at different points in time. The tank may, therefore, need to comply with two distinct sets of requirements, depending on the product that is stored. Both sets of requirements are included in the permit, so that the permit holder may store either product in the tank.

Determination of Applicable Requirements

Unit ID	Regulation	Index Number	Basis of Determination*	Changes and Exceptions to DSS**
OC5RX2100	40 CFR Part 63, Subpart G	63G-01	UNIT TYPE = EMISSION UNIT	The site specific MACT citations were determined from an analysis of the rule text and the basis of determination
OC5RX2110	40 CFR Part 63, Subpart G	63G-01	UNIT TYPE = EMISSION UNIT	The site specific MACT citations were determined from an analysis of the rule text and the basis of determination
A70ECGE503	30 TAC Chapter 117, Subchapter B	R7ICI-01	Type of Service = New, modified, reconstructed or relocated diesel fuel-fired engine, placed into service on or after October 1, 2001, located in the Houston/Galveston/Brazoria ozone nonattainment area, operated less than 100 hours/year, on a rolling 12-month average	
A70ECGE503	40 CFR Part 60, Subpart IIII	60IIII-01	<p>Applicability Date = Stationary CI ICE commenced construction, reconstruction, or modification after 07/11/2005.</p> <p>Exemptions = The CI ICE is not exempt due to national security, testing at an engine test cell/stand or as a temporary replacement.</p> <p>Service = CI ICE is a fire-pump engine, an emergency engine certified to National Fire Protection Association requirements.</p> <p>Commencing = CI ICE was newly constructed after 07/11/2005</p> <p>Manufacture Date = Date of manufacture was after 07/01/2006.</p> <p>Diesel = Diesel fuel is used.</p> <p>Displacement = Displacement is greater than or equal to 15 and less than 20 liters per cylinder.</p> <p>Model Year = CI ICE was manufactured in model year 2012.</p> <p>Kilowatts = Power rating is greater than or equal to 130 KW and less than or equal to 368 KW.</p> <p>Standard = The emergency CI ICE meets the Tier 1, 2, 3, or 4 standards applicable to non-emergency engines (for the same KW and model year)</p> <p>Compliance Option = The CI ICE and control device is installed, configured, operated, and maintained according to the manufacturer's emission-related written instructions.</p>	
A70ECGE503	40 CFR Part 63, Subpart ZZZZ	63ZZZZ-01	<p>HAP Source = The site is a major source of hazardous air pollutants as defined in 40 CFR § 63.2</p> <p>Brake HP = Stationary RICE with a brake HP greater than or equal to 300 HP and less than or equal to 500 HP.</p> <p>Construction/Reconstruction Date = Commenced construction or reconstruction on or after June 12, 2006.</p> <p>Service Type = Limited use.</p>	

Unit ID	Regulation	Index Number	Basis of Determination*	Changes and Exceptions to DSS**
OC5U5GE500	30 TAC Chapter 117, Subchapter B	R7ICI-01	<p>Type of Service = Used exclusively in emergency situations [claiming the emergency service exemption under 30 TAC §§ 117.103(a)(6)(D), 117.203(a)(6)(D), 117.303(a)(6)(D) or 117.403(a)(7)(D)]</p> <p>Fuel Fired = Petroleum-based diesel fuel</p>	
OC5U5GE500	40 CFR Part 63, Subpart ZZZZ	63ZZZZ-01	<p>HAP Source = The site is a major source of hazardous air pollutants as defined in 40 CFR § 63.2</p> <p>Brake HP = Stationary RICE with a brake HP greater than 500 HP.</p> <p>Construction/Reconstruction Date = Commenced construction or reconstruction on or after December 19, 2002, but before June 12, 2006.</p> <p>Service Type = Limited use.</p>	
A40ECST80A	30 TAC Chapter 115, Storage of VOCs	R5112-01	<p>Alternate Control Requirement = Not using an alternate method for demonstrating and documenting continuous compliance with applicable control requirements or exemption criteria.</p> <p>Product Stored = VOC other than crude oil or condensate</p> <p>Storage Capacity = Capacity is greater than 40,000 gallons</p> <p>Tank Description = Tank using a submerged fill pipe and vapor recovery system</p> <p>True Vapor Pressure = True vapor pressure is greater than or equal to 1.5 psia</p> <p>Control Device Type = Carbon adsorption system</p>	
A40ECST80A	40 CFR Part 63, Subpart G	63G-01	<p>MACT Subpart F/G Applicability = The unit is a Group 1 vessel (as defined in Table 5 for existing sources or Table 6 for new sources of 40 CFR 63, Subpart G).</p> <p>NESHAP Subpart Y Applicability = The unit is not subject to 40 CFR Part 61, Subpart Y.</p> <p>Maximum TVP = Maximum true vapor pressure of the total organic HAP in the liquid is less than 11.11 psi (76.6 kPa)</p> <p>Emission Control Type = Closed vent system (CVS) and control device (fixed roof)</p> <p>Closed Vent System = Closed vent system is subject to § 63.172 of Subpart H.</p> <p>Bypass Lines = Closed vent system has no by-pass lines.</p> <p>Control Device Type = Carbon adsorber</p> <p>Control Device Design = The control device was installed on or before December 31, 1992 and was designed to reduce inlet emissions of total organic hazardous air pollutants by greater than or equal to 90% and less than 95%.</p> <p>Design Evaluation Submitted = A design evaluation of the emission control system was submitted to demonstrate compliance with 40 CFR § 63.119(e).</p>	

Unit ID	Regulation	Index Number	Basis of Determination*	Changes and Exceptions to DSS**
A40ECST80B	30 TAC Chapter 115, Storage of VOCs	R5112-01	<p>Alternate Control Requirement = Not using an alternate method for demonstrating and documenting continuous compliance with applicable control requirements or exemption criteria.</p> <p>Product Stored = VOC other than crude oil or condensate</p> <p>Storage Capacity = Capacity is greater than 40,000 gallons</p> <p>Tank Description = Tank using a submerged fill pipe and vapor recovery system</p> <p>True Vapor Pressure = True vapor pressure is greater than or equal to 1.5 psia</p> <p>Control Device Type = Carbon adsorption system</p>	
A40ECST80B	40 CFR Part 63, Subpart G	63G-01	<p>MACT Subpart F/G Applicability = The unit is a Group 1 vessel (as defined in Table 5 for existing sources or Table 6 for new sources of 40 CFR 63, Subpart G).</p> <p>NESHAP Subpart Y Applicability = The unit is not subject to 40 CFR Part 61, Subpart Y.</p> <p>Maximum TVP = Maximum true vapor pressure of the total organic HAP in the liquid is less than 11.11 psi (76.6 kPa)</p> <p>Emission Control Type = Closed vent system (CVS) and control device (fixed roof)</p> <p>Closed Vent System = Closed vent system is subject to § 63.172 of Subpart H.</p> <p>Bypass Lines = Closed vent system has no by-pass lines.</p> <p>Control Device Type = Carbon adsorber</p> <p>Control Device Design = The control device was installed on or before December 31, 1992 and was designed to reduce inlet emissions of total organic hazardous air pollutants by greater than or equal to 90% and less than 95%.</p> <p>Design Evaluation Submitted = A design evaluation of the emission control system was submitted to demonstrate compliance with 40 CFR § 63.119(e).</p>	
A50ECST10	30 TAC Chapter 115, Storage of VOCs	R5112-01	<p>Alternate Control Requirement = Not using an alternate method for demonstrating and documenting continuous compliance with applicable control requirements or exemption criteria.</p> <p>Product Stored = VOC other than crude oil or condensate</p> <p>Storage Capacity = Capacity is greater than 40,000 gallons</p> <p>Tank Description = Tank using an internal floating roof (IFR)</p> <p>True Vapor Pressure = True vapor pressure is greater than or equal to 1.5 psia</p> <p>Control Device Type = Other control device</p>	

Unit ID	Regulation	Index Number	Basis of Determination*	Changes and Exceptions to DSS**
A50ECST10	40 CFR Part 63, Subpart G	63G-01	<p>MACT Subpart F/G Applicability = The unit is a Group 1 vessel (as defined in Table 5 for existing sources or Table 6 for new sources of 40 CFR 63, Subpart G).</p> <p>NESHAP Subpart Y Applicability = The unit is not subject to 40 CFR Part 61, Subpart Y.</p> <p>Maximum TVP = Maximum true vapor pressure of the total organic HAP in the liquid is less than 11.11 psi (76.6 kPa)</p> <p>Emission Control Type = Internal floating roof</p> <p>Seal Type = Metallic shoe seal (as defined in 40 CFR § 63.111)</p>	
A50ECST20	30 TAC Chapter 115, Storage of VOCs	R5112-01	<p>Alternate Control Requirement = Not using an alternate method for demonstrating and documenting continuous compliance with applicable control requirements or exemption criteria.</p> <p>Product Stored = VOC other than crude oil or condensate</p> <p>Storage Capacity = Capacity is greater than 40,000 gallons</p> <p>Tank Description = Tank using an internal floating roof (IFR)</p> <p>True Vapor Pressure = True vapor pressure is greater than or equal to 1.5 psia</p> <p>Control Device Type = Other control device</p>	
A50ECST20	40 CFR Part 63, Subpart G	63G-01	<p>MACT Subpart F/G Applicability = The unit is a Group 1 vessel (as defined in Table 5 for existing sources or Table 6 for new sources of 40 CFR 63, Subpart G).</p> <p>NESHAP Subpart Y Applicability = The unit is not subject to 40 CFR Part 61, Subpart Y.</p> <p>Maximum TVP = Maximum true vapor pressure of the total organic HAP in the liquid is less than 11.11 psi (76.6 kPa)</p> <p>Emission Control Type = Internal floating roof</p> <p>Seal Type = Metallic shoe seal (as defined in 40 CFR § 63.111)</p>	
A50ECST30	30 TAC Chapter 115, Storage of VOCs	R5112-01	<p>Alternate Control Requirement = Not using an alternate method for demonstrating and documenting continuous compliance with applicable control requirements or exemption criteria.</p> <p>Product Stored = VOC other than crude oil or condensate</p> <p>Storage Capacity = Capacity is greater than 40,000 gallons</p> <p>Tank Description = Tank using an internal floating roof (IFR)</p> <p>True Vapor Pressure = True vapor pressure is greater than or equal to 1.5 psia</p> <p>Control Device Type = Other control device</p>	

Unit ID	Regulation	Index Number	Basis of Determination*	Changes and Exceptions to DSS**
A50ECST30	40 CFR Part 63, Subpart G	63G-01	<p>MACT Subpart F/G Applicability = The unit is a Group 1 vessel (as defined in Table 5 for existing sources or Table 6 for new sources of 40 CFR 63, Subpart G).</p> <p>NESHAP Subpart Y Applicability = The unit is not subject to 40 CFR Part 61, Subpart Y.</p> <p>Maximum TVP = Maximum true vapor pressure of the total organic HAP in the liquid is less than 11.11 psi (76.6 kPa)</p> <p>Emission Control Type = Internal floating roof</p> <p>Seal Type = Metallic shoe seal (as defined in 40 CFR § 63.111)</p>	
A70ECST402	30 TAC Chapter 115, Storage of VOCs	R5112-01	<p>Alternate Control Requirement = Not using an alternate method for demonstrating and documenting continuous compliance with applicable control requirements or exemption criteria.</p> <p>Product Stored = VOC other than crude oil or condensate</p> <p>Storage Capacity = Capacity is greater than 40,000 gallons</p> <p>Tank Description = Tank does not require emission controls</p> <p>True Vapor Pressure = True vapor pressure is less than 1.0 psia</p>	
A70ECST502	30 TAC Chapter 115, Storage of VOCs	R5112-01	<p>Alternate Control Requirement = Not using an alternate method for demonstrating and documenting continuous compliance with applicable control requirements or exemption criteria.</p> <p>Product Stored = VOC other than crude oil or condensate</p> <p>Storage Capacity = Capacity is greater than 40,000 gallons</p> <p>Tank Description = Tank does not require emission controls</p> <p>True Vapor Pressure = True vapor pressure is less than 1.0 psia</p>	
A70ECST502	40 CFR Part 63, Subpart G	63G-01	<p>MACT Subpart F/G Applicability = The unit is a Group 2 vessel.</p> <p>NESHAP Subpart Y Applicability = The unit is not subject to 40 CFR Part 61, Subpart Y.</p> <p>NSPS Subpart Kb Applicability = The unit is not subject to 40 CFR Part 60, Subpart Kb.</p>	
A70ECST51A	30 TAC Chapter 115, Storage of VOCs	R5112-01	<p>Alternate Control Requirement = Not using an alternate method for demonstrating and documenting continuous compliance with applicable control requirements or exemption criteria.</p> <p>Product Stored = VOC other than crude oil or condensate</p> <p>Storage Capacity = Capacity is greater than 40,000 gallons</p> <p>Tank Description = Tank using a vapor recovery system (VRS)</p> <p>True Vapor Pressure = True vapor pressure is greater than or equal to 1.5 psia</p> <p>Control Device Type = Direct-flame incinerator</p>	

Unit ID	Regulation	Index Number	Basis of Determination*	Changes and Exceptions to DSS**
A70ECST51B	30 TAC Chapter 115, Storage of VOCs	R5112-01	<p>Alternate Control Requirement = Not using an alternate method for demonstrating and documenting continuous compliance with applicable control requirements or exemption criteria.</p> <p>Product Stored = VOC other than crude oil or condensate</p> <p>Storage Capacity = Capacity is greater than 40,000 gallons</p> <p>Tank Description = Tank using a vapor recovery system (VRS)</p> <p>True Vapor Pressure = True vapor pressure is greater than or equal to 1.5 psia</p> <p>Control Device Type = Direct-flame incinerator</p>	
A70ST401A	30 TAC Chapter 115, Storage of VOCs	R5112-01	<p>Alternate Control Requirement = Not using an alternate method for demonstrating and documenting continuous compliance with applicable control requirements or exemption criteria.</p> <p>Product Stored = VOC other than crude oil or condensate</p> <p>Storage Capacity = Capacity is greater than 40,000 gallons</p> <p>Tank Description = Tank using an internal floating roof (IFR)</p> <p>True Vapor Pressure = True vapor pressure is greater than or equal to 1.5 psia</p>	
A70ST401A	40 CFR Part 63, Subpart EEEE	63EEEE-01	Product Stored = Organic HAP containing liquid other than crude oil.	
OC5ST2105	30 TAC Chapter 115, Storage of VOCs	R5112-01	<p>Alternate Control Requirement = Not using an alternate method for demonstrating and documenting continuous compliance with applicable control requirements or exemption criteria.</p> <p>Product Stored = VOC other than crude oil or condensate</p> <p>Storage Capacity = Capacity is greater than 1,000 gallons but less than or equal to 25,000 gallons</p> <p>Tank Description = Tank does not require emission controls</p> <p>True Vapor Pressure = True vapor pressure is less than 1.0 psia</p>	
OC5ST2160	30 TAC Chapter 115, Storage of VOCs	R5112-01	<p>Alternate Control Requirement = Not using an alternate method for demonstrating and documenting continuous compliance with applicable control requirements or exemption criteria.</p> <p>Product Stored = VOC other than crude oil or condensate</p> <p>Storage Capacity = Capacity is greater than 25,000 gallons but less than or equal to 40,000 gallons</p> <p>Tank Description = Tank does not require emission controls</p> <p>True Vapor Pressure = True vapor pressure is less than 1.0 psia</p>	

Unit ID	Regulation	Index Number	Basis of Determination*	Changes and Exceptions to DSS**
OC5ST2170	30 TAC Chapter 115, Storage of VOCs	R5112-01	<p>Alternate Control Requirement = Not using an alternate method for demonstrating and documenting continuous compliance with applicable control requirements or exemption criteria.</p> <p>Product Stored = VOC other than crude oil or condensate</p> <p>Storage Capacity = Capacity is greater than 40,000 gallons</p> <p>Tank Description = Tank using a vapor recovery system (VRS)</p> <p>True Vapor Pressure = True vapor pressure is greater than or equal to 1.5 psia</p> <p>Control Device Type = Direct-flame incinerator</p>	
OC5ST2485	30 TAC Chapter 115, Storage of VOCs	R5112-01	<p>Alternate Control Requirement = Not using an alternate method for demonstrating and documenting continuous compliance with applicable control requirements or exemption criteria.</p> <p>Product Stored = VOC other than crude oil or condensate</p> <p>Storage Capacity = Capacity is greater than 40,000 gallons</p> <p>Tank Description = Tank using a vapor recovery system (VRS)</p> <p>True Vapor Pressure = True vapor pressure is greater than or equal to 1.5 psia</p> <p>Control Device Type = Direct-flame incinerator</p>	
OC5ST2485	40 CFR Part 63, Subpart EEEE	63EEEE-01	Product Stored = Organic HAP containing liquid other than crude oil.	
OC5ST2486	30 TAC Chapter 115, Storage of VOCs	R5112-01	<p>Alternate Control Requirement = Not using an alternate method for demonstrating and documenting continuous compliance with applicable control requirements or exemption criteria.</p> <p>Product Stored = VOC other than crude oil or condensate</p> <p>Storage Capacity = Capacity is greater than 40,000 gallons</p> <p>Tank Description = Tank using a vapor recovery system (VRS)</p> <p>True Vapor Pressure = True vapor pressure is greater than or equal to 1.5 psia</p> <p>Control Device Type = Direct-flame incinerator</p>	
OC5ST2486	40 CFR Part 63, Subpart EEEE	63EEEE-01	Product Stored = Organic HAP containing liquid other than crude oil.	
OC5ST250	30 TAC Chapter 115, Storage of VOCs	R5112-01	<p>Alternate Control Requirement = Not using an alternate method for demonstrating and documenting continuous compliance with applicable control requirements or exemption criteria.</p> <p>Product Stored = VOC other than crude oil or condensate</p>	

Unit ID	Regulation	Index Number	Basis of Determination*	Changes and Exceptions to DSS**
			<p>Storage Capacity = Capacity is greater than 40,000 gallons</p> <p>Tank Description = Tank using a vapor recovery system (VRS)</p> <p>True Vapor Pressure = True vapor pressure is greater than or equal to 1.5 psia</p> <p>Control Device Type = Direct-flame incinerator</p>	
OC5ST5	30 TAC Chapter 115, Storage of VOCs	R5112-01	<p>Alternate Control Requirement = Not using an alternate method for demonstrating and documenting continuous compliance with applicable control requirements or exemption criteria.</p> <p>Product Stored = VOC other than crude oil or condensate</p> <p>Storage Capacity = Capacity is greater than 1,000 gallons but less than or equal to 25,000 gallons</p> <p>Tank Description = Tank using a vapor recovery system (VRS)</p> <p>True Vapor Pressure = True vapor pressure is greater than or equal to 1.5 psia</p> <p>Control Device Type = Direct-flame incinerator</p>	
OC5U5ST500	30 TAC Chapter 115, Storage of VOCs	R5112-01	<p>Alternate Control Requirement = Not using an alternate method for demonstrating and documenting continuous compliance with applicable control requirements or exemption criteria.</p> <p>Product Stored = VOC other than crude oil or condensate</p> <p>Storage Capacity = Capacity is less than or equal to 1,000 gallons</p>	
OC5U5STV10	30 TAC Chapter 115, Storage of VOCs	R5112-01	<p>Alternate Control Requirement = Not using an alternate method for demonstrating and documenting continuous compliance with applicable control requirements or exemption criteria.</p> <p>Product Stored = VOC other than crude oil or condensate</p> <p>Storage Capacity = Capacity is greater than 40,000 gallons</p> <p>Tank Description = Tank using a vapor recovery system (VRS)</p> <p>True Vapor Pressure = True vapor pressure is greater than or equal to 1.5 psia</p> <p>Control Device Type = Direct-flame incinerator</p>	
OC9ST260	30 TAC Chapter 115, Storage of VOCs	R5112-01	<p>Alternate Control Requirement = Not using an alternate method for demonstrating and documenting continuous compliance with applicable control requirements or exemption criteria.</p> <p>Product Stored = VOC other than crude oil or condensate</p> <p>Storage Capacity = Capacity is greater than 40,000 gallons</p> <p>Tank Description = Tank using a vapor recovery system (VRS)</p> <p>True Vapor Pressure = True vapor pressure is greater than or equal to 1.5 psia</p>	

Unit ID	Regulation	Index Number	Basis of Determination*	Changes and Exceptions to DSS**
			Control Device Type = Direct-flame incinerator	
OC9ST261	30 TAC Chapter 115, Storage of VOCs	R5112-01	<p>Alternate Control Requirement = Not using an alternate method for demonstrating and documenting continuous compliance with applicable control requirements or exemption criteria.</p> <p>Product Stored = VOC other than crude oil or condensate</p> <p>Storage Capacity = Capacity is greater than 40,000 gallons</p> <p>Tank Description = Tank using a vapor recovery system (VRS)</p> <p>True Vapor Pressure = True vapor pressure is greater than or equal to 1.5 psia</p> <p>Control Device Type = Direct-flame incinerator</p>	
OC9ST262	30 TAC Chapter 115, Storage of VOCs	R5112-01	<p>Alternate Control Requirement = Not using an alternate method for demonstrating and documenting continuous compliance with applicable control requirements or exemption criteria.</p> <p>Product Stored = VOC other than crude oil or condensate</p> <p>Storage Capacity = Capacity is greater than 40,000 gallons</p> <p>Tank Description = Tank using a vapor recovery system (VRS)</p> <p>True Vapor Pressure = True vapor pressure is greater than or equal to 1.5 psia</p> <p>Control Device Type = Direct-flame incinerator</p>	
OC9ST270	30 TAC Chapter 115, Storage of VOCs	R5112-01	<p>Alternate Control Requirement = Not using an alternate method for demonstrating and documenting continuous compliance with applicable control requirements or exemption criteria.</p> <p>Product Stored = VOC other than crude oil or condensate</p> <p>Storage Capacity = Capacity is greater than 40,000 gallons</p> <p>Tank Description = Tank using a vapor recovery system (VRS)</p> <p>True Vapor Pressure = True vapor pressure is greater than or equal to 1.5 psia</p> <p>Control Device Type = Direct-flame incinerator</p>	
OC9ST270	40 CFR Part 63, Subpart EEEE	63EEEE-01	Product Stored = Organic HAP containing liquid other than crude oil.	
A14ECMLPSA	30 TAC Chapter 115, Loading and Unloading of VOC	R5211-01	<p>Chapter 115 Facility Type = Marine terminal</p> <p>Alternate Control Requirement (ACR) = Using the 90% overall control option specified in 30 TAC § 115.213(d).</p> <p>Product Transferred = Volatile organic compounds other than liquefied petroleum gas and gasoline.</p>	

Unit ID	Regulation	Index Number	Basis of Determination*	Changes and Exceptions to DSS**
			<p>Transfer Type = Loading and unloading.</p> <p>True Vapor Pressure = True vapor pressure is greater than or equal to 0.5 and less than 11.0 psia, the overall emission controls are at least 90%, and an initial control plan and annual report has been submitted.</p> <p>Daily Throughput = Daily throughput not determined since 30 TAC § 115.217(a)(2)(B), (b)(3)(B), (a)(2)(A), and (b)(3)(A) exemptions do not apply to marine terminals or gasoline terminals.</p> <p>Control Options = Vapor control system that maintains a control efficiency of at least 90%.</p> <p>Chapter 115 Control Device Type = Vapor control system with a carbon adsorption system.</p> <p>Vapor Tight = All liquid and vapor lines are equipped with fittings which make vapor-tight connections that close automatically when disconnected.</p> <p>Marine Terminal Exemptions = The marine terminal is not claiming one or more of the loading exemptions in 30 TAC § 115.217(a)(5)(B).</p>	
A24ECLR1	30 TAC Chapter 115, Loading and Unloading of VOC	R5211-01	<p>Chapter 115 Facility Type = Facility type other than a gasoline terminal, gasoline bulk plant, motor vehicle fuel dispensing facility or marine terminal.</p> <p>Alternate Control Requirement (ACR) = Using the 90% overall control option specified in 30 TAC § 115.213(b).</p> <p>Product Transferred = Volatile organic compounds other than liquefied petroleum gas and gasoline.</p> <p>Transfer Type = Only loading.</p> <p>True Vapor Pressure = True vapor pressure is greater than or equal to 0.5 and less than 11.0 psia, the overall emission controls are at least 90%, and an initial control plan and annual report has been submitted.</p> <p>Daily Throughput = Daily throughput not determined since 30 TAC § 115.217(a)(2)(A) or 30 TAC § 115.217(b)(3)(A) exemption is not utilized.</p> <p>Control Options = Vapor control system that maintains a control efficiency of at least 90%.</p> <p>Chapter 115 Control Device Type = Control device other than a flare, vapor combustor, catalytic incinerator, direct flame incinerator, chiller, or carbon adsorption system.</p> <p>Vapor Tight = All liquid and vapor lines are equipped with fittings which make vapor-tight connections that close automatically when disconnected.</p>	
A24ECLR1	30 TAC Chapter 115, Loading and Unloading of VOC	R5211-02	<p>Chapter 115 Facility Type = Facility type other than a gasoline terminal, gasoline bulk plant, motor vehicle fuel dispensing facility or marine terminal.</p>	

Unit ID	Regulation	Index Number	Basis of Determination*	Changes and Exceptions to DSS**
			<p>Alternate Control Requirement (ACR) = Using the 90% overall control option specified in 30 TAC § 115.213(b).</p> <p>Product Transferred = Volatile organic compounds other than liquefied petroleum gas and gasoline.</p> <p>Transfer Type = Only loading.</p> <p>True Vapor Pressure = True vapor pressure is greater than or equal to 0.5 and less than 11.0 psia, the overall emission controls are at least 90%, and an initial control plan and annual report has been submitted.</p> <p>Daily Throughput = Daily throughput not determined since 30 TAC § 115.217(a)(2)(A) or 30 TAC § 115.217(b)(3)(A) exemption is not utilized.</p> <p>Control Options = Vapor control system that maintains a control efficiency of at least 90%.</p> <p>Chapter 115 Control Device Type = Control device other than a flare, vapor combustor, catalytic incinerator, direct flame incinerator, chiller, or carbon adsorption system.</p> <p>Vapor Tight = All liquid and vapor lines are equipped with fittings which make vapor-tight connections that close automatically when disconnected.</p>	
A35MRLR1	30 TAC Chapter 115, Loading and Unloading of VOC	R5211-01	<p>Chapter 115 Facility Type = Facility type other than a gasoline terminal, gasoline bulk plant, motor vehicle fuel dispensing facility or marine terminal.</p> <p>Alternate Control Requirement (ACR) = Using the 90% overall control option specified in 30 TAC § 115.213(b).</p> <p>Product Transferred = Volatile organic compounds other than liquefied petroleum gas and gasoline.</p> <p>Transfer Type = Only loading.</p> <p>True Vapor Pressure = True vapor pressure is greater than or equal to 0.5 and less than 11.0 psia, the overall emission controls are at least 90%, and an initial control plan and annual report has been submitted.</p> <p>Daily Throughput = Daily throughput not determined since 30 TAC § 115.217(a)(2)(A) or 30 TAC § 115.217(b)(3)(A) exemption is not utilized.</p> <p>Control Options = Vapor control system that maintains a control efficiency of at least 90%.</p> <p>Chapter 115 Control Device Type = No control device.</p> <p>Vapor Tight = Not all liquid and vapor lines are equipped with fittings which make vapor-tight connections that close automatically when disconnected.</p>	
A70ECLR1	30 TAC Chapter 115, Loading and	R5211-01	<p>Chapter 115 Facility Type = Facility type other than a gasoline terminal, gasoline bulk plant, motor vehicle fuel dispensing facility or marine terminal.</p>	

Unit ID	Regulation	Index Number	Basis of Determination*	Changes and Exceptions to DSS**
	Unloading of VOC		<p>Alternate Control Requirement (ACR) = Using the 90% overall control option specified in 30 TAC § 115.213(b).</p> <p>Product Transferred = Volatile organic compounds other than liquefied petroleum gas and gasoline.</p> <p>Transfer Type = Loading and unloading.</p> <p>True Vapor Pressure = True vapor pressure is greater than or equal to 0.5 and less than 11.0 psia, the overall emission controls are at least 90%, and an initial control plan and annual report has been submitted.</p> <p>Daily Throughput = Daily throughput not determined since 30 TAC § 115.217(a)(2)(A) or 30 TAC § 115.217(b)(3)(A) exemption is not utilized.</p> <p>Control Options = Vapor balance system.</p> <p>Chapter 115 Control Device Type = No control device.</p>	
A70ECLR1	40 CFR Part 63, Subpart G	63G-01	<p>Transfer Rack Type = Group 2 transfer rack (as defined in 40 CFR § 63.111).</p> <p>Subject to Subpart BB = The transfer rack is not subject to 40 CFR Part 61, Subpart BB.</p>	
OC1LR803	30 TAC Chapter 115, Loading and Unloading of VOC	R5211-01	<p>Chapter 115 Facility Type = Facility type other than a gasoline terminal, gasoline bulk plant, motor vehicle fuel dispensing facility or marine terminal.</p> <p>Alternate Control Requirement (ACR) = No alternate control requirements are being utilized.</p> <p>Product Transferred = Volatile organic compounds other than liquefied petroleum gas and gasoline.</p> <p>Transfer Type = Only unloading.</p> <p>True Vapor Pressure = True vapor pressure greater than or equal to 0.5 psia.</p> <p>Daily Throughput = Daily throughput not determined since 30 TAC § 115.217(a)(2)(A) or 30 TAC § 115.217(b)(3)(A) exemption is not utilized.</p> <p>Control Options = Vapor control system that maintains a control efficiency of at least 90%.</p> <p>Chapter 115 Control Device Type = Vapor control system with a direct flame incinerator.</p> <p>Vapor Tight = Not all liquid and vapor lines are equipped with fittings which make vapor-tight connections that close automatically when disconnected.</p>	
OC5U5LR1	30 TAC Chapter 115, Loading and	R5211-01	<p>Chapter 115 Facility Type = Facility type other than a gasoline terminal, gasoline bulk plant, motor vehicle fuel dispensing facility or marine terminal.</p>	

Unit ID	Regulation	Index Number	Basis of Determination*	Changes and Exceptions to DSS**
	Unloading of VOC		<p>Alternate Control Requirement (ACR) = No alternate control requirements are being utilized.</p> <p>Product Transferred = Volatile organic compounds other than liquefied petroleum gas and gasoline.</p> <p>Transfer Type = Only unloading.</p> <p>True Vapor Pressure = True vapor pressure greater than or equal to 0.5 psia.</p> <p>Daily Throughput = Daily throughput not determined since 30 TAC § 115.217(a)(2)(A) or 30 TAC § 115.217(b)(3)(A) exemption is not utilized.</p> <p>Control Options = Vapor balance system.</p> <p>Chapter 115 Control Device Type = No control device.</p> <p>Vapor Tight = All liquid and vapor lines are equipped with fittings which make vapor-tight connections that close automatically when disconnected.</p>	
OC5U5LR2	30 TAC Chapter 115, Loading and Unloading of VOC	R5211-01	<p>Chapter 115 Facility Type = Facility type other than a gasoline terminal, gasoline bulk plant, motor vehicle fuel dispensing facility or marine terminal.</p> <p>Alternate Control Requirement (ACR) = Using the 90% overall control option specified in 30 TAC § 115.213(b).</p> <p>Product Transferred = Volatile organic compounds other than liquefied petroleum gas and gasoline.</p> <p>Transfer Type = Loading and unloading.</p> <p>True Vapor Pressure = True vapor pressure is greater than or equal to 0.5 and less than 11.0 psia, the overall emission controls are at least 90%, and an initial control plan and annual report has been submitted.</p> <p>Daily Throughput = Daily throughput not determined since 30 TAC § 115.217(a)(2)(A) or 30 TAC § 115.217(b)(3)(A) exemption is not utilized.</p> <p>Control Options = Vapor balance system.</p> <p>Chapter 115 Control Device Type = No control device.</p>	
OC5U5LR2	40 CFR Part 63, Subpart G	63G-01	<p>Transfer Rack Type = Group 1 transfer rack (as defined in 40 CFR § 63.111).</p> <p>Closed Vent System = Closed vent system is subject to § 63.172 of Subpart H.</p> <p>Vapor Balancing System = A vapor balancing system is being used to reduce emissions of organic hazardous air pollutants.</p> <p>Bypass Lines = The vent system does not contain by-pass lines that could divert a vent stream flow away from the control device.</p>	

Unit ID	Regulation	Index Number	Basis of Determination*	Changes and Exceptions to DSS**
OC5U5TL1	30 TAC Chapter 115, Loading and Unloading of VOC	R5211-01	<p>Chapter 115 Facility Type = Facility type other than a gasoline terminal, gasoline bulk plant, motor vehicle fuel dispensing facility or marine terminal.</p> <p>Alternate Control Requirement (ACR) = Using the 90% overall control option specified in 30 TAC § 115.213(b).</p> <p>Product Transferred = Volatile organic compounds other than liquefied petroleum gas and gasoline.</p> <p>Transfer Type = Only loading.</p> <p>True Vapor Pressure = True vapor pressure is greater than or equal to 0.5 and less than 11.0 psia, the overall emission controls are at least 90%, and an initial control plan and annual report has been submitted.</p> <p>Daily Throughput = Daily throughput not determined since 30 TAC § 115.217(a)(2)(A) or 30 TAC § 115.217(b)(3)(A) exemption is not utilized.</p> <p>Control Options = Vapor balance system.</p> <p>Chapter 115 Control Device Type = No control device.</p>	
OC5U5TL1	40 CFR Part 63, Subpart G	63G-01	<p>Transfer Rack Type = Group 2 transfer rack (as defined in 40 CFR § 63.111).</p> <p>Subject to Subpart BB = The transfer rack is not subject to 40 CFR Part 61, Subpart BB.</p>	
OC5U5TL2	30 TAC Chapter 115, Loading and Unloading of VOC	R5211-01	<p>Chapter 115 Facility Type = Facility type other than a gasoline terminal, gasoline bulk plant, motor vehicle fuel dispensing facility or marine terminal.</p> <p>Alternate Control Requirement (ACR) = Using the 90% overall control option specified in 30 TAC § 115.213(b).</p> <p>Product Transferred = Volatile organic compounds other than liquefied petroleum gas and gasoline.</p> <p>Transfer Type = Loading and unloading.</p> <p>True Vapor Pressure = True vapor pressure is greater than or equal to 0.5 and less than 11.0 psia, the overall emission controls are at least 90%, and an initial control plan and annual report has been submitted.</p> <p>Daily Throughput = Daily throughput not determined since 30 TAC § 115.217(a)(2)(A) or 30 TAC § 115.217(b)(3)(A) exemption is not utilized.</p> <p>Control Options = Vapor balance system.</p> <p>Chapter 115 Control Device Type = No control device.</p>	
OC5U5TL2	40 CFR Part 63, Subpart G	63G-01	<p>Transfer Rack Type = Group 2 transfer rack (as defined in 40 CFR § 63.111).</p> <p>Subject to Subpart BB = The transfer rack is not subject to 40 CFR Part 61, Subpart BB.</p>	

Unit ID	Regulation	Index Number	Basis of Determination*	Changes and Exceptions to DSS**
OC5U5UL1	30 TAC Chapter 115, Loading and Unloading of VOC	R5211-01	<p>Chapter 115 Facility Type = Facility type other than a gasoline terminal, gasoline bulk plant, motor vehicle fuel dispensing facility or marine terminal.</p> <p>Alternate Control Requirement (ACR) = No alternate control requirements are being utilized.</p> <p>Product Transferred = Volatile organic compounds other than liquefied petroleum gas and gasoline.</p> <p>Transfer Type = Only unloading.</p> <p>True Vapor Pressure = True vapor pressure less than 0.5 psia.</p>	
OC5U5UL2	30 TAC Chapter 115, Loading and Unloading of VOC	R5211-01	<p>Chapter 115 Facility Type = Facility type other than a gasoline terminal, gasoline bulk plant, motor vehicle fuel dispensing facility or marine terminal.</p> <p>Alternate Control Requirement (ACR) = No alternate control requirements are being utilized.</p> <p>Product Transferred = Volatile organic compounds other than liquefied petroleum gas and gasoline.</p> <p>Transfer Type = Only unloading.</p> <p>True Vapor Pressure = True vapor pressure less than 0.5 psia.</p>	
OC5U5ULRTR	30 TAC Chapter 115, Loading and Unloading of VOC	R5211-01	<p>Chapter 115 Facility Type = Facility type other than a gasoline terminal, gasoline bulk plant, motor vehicle fuel dispensing facility or marine terminal.</p> <p>Alternate Control Requirement (ACR) = No alternate control requirements are being utilized.</p> <p>Product Transferred = Volatile organic compounds other than liquefied petroleum gas and gasoline.</p> <p>Transfer Type = Only unloading.</p> <p>True Vapor Pressure = True vapor pressure greater than or equal to 0.5 psia.</p> <p>Daily Throughput = Daily throughput not determined since 30 TAC § 115.217(a)(2)(A) or 30 TAC § 115.217(b)(3)(A) exemption is not utilized.</p> <p>Control Options = Vapor balance system.</p> <p>Chapter 115 Control Device Type = No control device.</p> <p>Vapor Tight = Not all liquid and vapor lines are equipped with fittings which make vapor-tight connections that close automatically when disconnected.</p>	
OC9U5LRUL	30 TAC Chapter 115, Loading and	R5211-01	<p>Chapter 115 Facility Type = Facility type other than a gasoline terminal, gasoline bulk plant, motor vehicle fuel dispensing facility or marine terminal.</p>	

Unit ID	Regulation	Index Number	Basis of Determination*	Changes and Exceptions to DSS**
	Unloading of VOC		<p>Alternate Control Requirement (ACR) = No alternate control requirements are being utilized.</p> <p>Product Transferred = Volatile organic compounds other than liquefied petroleum gas and gasoline.</p> <p>Transfer Type = Only unloading.</p> <p>True Vapor Pressure = True vapor pressure greater than or equal to 0.5 psia.</p> <p>Daily Throughput = Daily throughput not determined since 30 TAC § 115.217(a)(2)(A) or 30 TAC § 115.217(b)(3)(A) exemption is not utilized.</p> <p>Control Options = Vapor balance system.</p> <p>Chapter 115 Control Device Type = No control device.</p> <p>Vapor Tight = All liquid and vapor lines are equipped with fittings which make vapor-tight connections that close automatically when disconnected.</p>	
OC9U5LRUL	40 CFR Part 63, Subpart EEEE	60EEEE-01	<p>Existing Source = Source is an existing source</p> <p>Transfer Operation = Transfer rack only unloads organic liquids</p> <p>Transfer Volume = Less than 800,000 gallons of organic containing liquids are transferred by the organic loading distribution facility annually.</p>	
OC5U5H201	30 TAC Chapter 117, Subchapter B	R7ICI-01	<p>Unit Type = Pyrolysis reactor</p> <p>Maximum Rated Capacity = MRC is greater than or equal to 40 MMBtu/hr but less than 100 MMBtu/hr</p> <p>Fuel Type #1 = Natural gas</p> <p>Annual Heat Input = Annual heat input is greater than 2.8 (10¹¹) Btu/yr, based on a rolling 12-month average.</p> <p>NOx Emission Limitation = Title 30 TAC §§ 117.310(d)(3) and 117.310(a)(8)</p> <p>Diluent CEMS = The process heater does not use a carbon dioxide CEMS to monitor diluent.</p> <p>NOx Emission Limit Basis = Emission limit basis is not a rolling 30-day average or a block one-hour average</p> <p>NOx Reduction = No NO_x reduction</p> <p>NOx Monitoring System = Continuous emissions monitoring system</p> <p>Fuel Flow Monitoring = Fuel flow is monitored with a totalizing fuel flow meter per 30 TAC §§ 117.140(a), 117.340(a) or 117.440(a).</p> <p>CO Emission Limitation = Title 30 TAC § 117.310(c)(1) 400 ppmv option</p> <p>CO Monitoring System = Emissions are monitored using method other than CEMS or PEMS.</p>	

Unit ID	Regulation	Index Number	Basis of Determination*	Changes and Exceptions to DSS**
OC5U5H202	30 TAC Chapter 117, Subchapter B	R71CI-01	<p>Unit Type = Pyrolysis reactor</p> <p>Maximum Rated Capacity = MRC is greater than or equal to 40 MMBtu/hr but less than 100 MMBtu/hr</p> <p>Fuel Type #1 = Natural gas</p> <p>Annual Heat Input = Annual heat input is greater than 2.8 (10¹¹) Btu/yr, based on a rolling 12-month average.</p> <p>NOx Emission Limitation = Title 30 TAC §§ 117.310(d)(3) and 117.310(a)(8)</p> <p>Diluent CEMS = The process heater does not use a carbon dioxide CEMS to monitor diluent.</p> <p>NOx Emission Limit Basis = Emission limit basis is not a rolling 30-day average or a block one-hour average</p> <p>NOx Reduction = No NO_x reduction</p> <p>NOx Monitoring System = Maximum emission rate testing [in accordance with 30 TAC § 117.8000]</p> <p>Fuel Flow Monitoring = Fuel flow is monitored with a totalizing fuel flow meter per 30 TAC §§ 117.140(a), 117.340(a) or 117.440(a).</p> <p>CO Emission Limitation = Title 30 TAC § 117.310(c)(1) 400 ppmv option</p> <p>CO Monitoring System = Emissions are monitored using method other than CEMS or PEMS.</p>	
OC5U5H203	30 TAC Chapter 117, Subchapter B	R71CI-01	<p>Unit Type = Pyrolysis reactor</p> <p>Maximum Rated Capacity = MRC is greater than or equal to 40 MMBtu/hr but less than 100 MMBtu/hr</p> <p>Fuel Type #1 = Natural gas</p> <p>Annual Heat Input = Annual heat input is greater than 2.8 (10¹¹) Btu/yr, based on a rolling 12-month average.</p> <p>NOx Emission Limitation = Title 30 TAC §§ 117.310(d)(3) and 117.310(a)(8)</p> <p>Diluent CEMS = The process heater does not use a carbon dioxide CEMS to monitor diluent.</p> <p>NOx Emission Limit Basis = Emission limit basis is not a rolling 30-day average or a block one-hour average</p> <p>NOx Reduction = No NO_x reduction</p> <p>NOx Monitoring System = Maximum emission rate testing [in accordance with 30 TAC § 117.8000]</p> <p>Fuel Flow Monitoring = Fuel flow is monitored with a totalizing fuel flow meter per 30 TAC §§ 117.140(a), 117.340(a) or 117.440(a).</p> <p>CO Emission Limitation = Title 30 TAC § 117.310(c)(1) 400 ppmv option</p> <p>CO Monitoring System = Emissions are monitored using method other than CEMS or PEMS.</p>	

Unit ID	Regulation	Index Number	Basis of Determination*	Changes and Exceptions to DSS**
OC5U5H204	30 TAC Chapter 117, Subchapter B	R7ICI-01	<p>Unit Type = Pyrolysis reactor</p> <p>Maximum Rated Capacity = MRC is greater than or equal to 40 MMBtu/hr but less than 100 MMBtu/hr</p> <p>Fuel Type #1 = Natural gas</p> <p>Annual Heat Input = Annual heat input is greater than 2.8 (10¹¹) Btu/yr, based on a rolling 12-month average.</p> <p>NOx Emission Limitation = Title 30 TAC §§ 117.310(d)(3) and 117.310(a)(8)</p> <p>Diluent CEMS = The process heater does not use a carbon dioxide CEMS to monitor diluent.</p> <p>NOx Emission Limit Basis = Emission limit basis is not a rolling 30-day average or a block one-hour average</p> <p>NOx Reduction = No NO_x reduction</p> <p>NOx Monitoring System = Maximum emission rate testing [in accordance with 30 TAC § 117.8000]</p> <p>Fuel Flow Monitoring = Fuel flow is monitored with a totalizing fuel flow meter per 30 TAC §§ 117.140(a), 117.340(a) or 117.440(a).</p> <p>CO Emission Limitation = Title 30 TAC § 117.310(c)(1) 400 ppmv option</p> <p>CO Monitoring System = Emissions are monitored using method other than CEMS or PEMS.</p>	
OC5U5H206	40 CFR Part 63, Subpart DDDDD	63DDDDD-01	<p>Commence = Source is existing (commenced construction or reconstruction on or before June 4, 2010)</p> <p>Table Applicability = The unit is designed to burn Gas 1 fuel AND has no continuous oxygen trim AND has heat input equal to or greater than 10 MMBtu/hr</p>	
OC5U5H207	40 CFR Part 63, Subpart DDDDD	63DDDDD-01	<p>Commence = Source is existing (commenced construction or reconstruction on or before June 4, 2010)</p> <p>Table Applicability = The unit is designed to burn Gas 1 fuel AND has no continuous oxygen trim AND has heat input equal to or greater than 10 MMBtu/hr</p>	
OC5U5H208	30 TAC Chapter 117, Subchapter B	R7ICI-01	<p>Unit Type = Process heater</p> <p>Maximum Rated Capacity = MRC is greater than 2 MMBtu/hr but less than 40 MMBtu/hr</p> <p>Fuel Type #1 = Natural gas</p> <p>NOx Emission Limitation = Title 30 TAC §§ 117.310(d)(3) and 117.310(a)(8)</p> <p>Diluent CEMS = The process heater does not use a carbon dioxide CEMS to monitor diluent.</p>	

Unit ID	Regulation	Index Number	Basis of Determination*	Changes and Exceptions to DSS**
			<p>NOx Emission Limit Basis = Emission limit basis is not a rolling 30-day average or a block one-hour average</p> <p>NOx Reduction = No NO_x reduction</p> <p>NOx Monitoring System = Maximum emission rate testing [in accordance with 30 TAC § 117.8000]</p> <p>Fuel Flow Monitoring = Fuel flow is monitored with a totalizing fuel flow meter per 30 TAC §§ 117.140(a), 117.340(a) or 117.440(a).</p> <p>CO Emission Limitation = Title 30 TAC § 117.310(c)(1) 400 ppmv option</p> <p>CO Monitoring System = Emissions are monitored using method other than CEMS or PEMS.</p>	
OC5U5H209	30 TAC Chapter 117, Subchapter B	R7ICI-01	<p>Unit Type = Process heater</p> <p>Maximum Rated Capacity = MRC is greater than 2 MMBtu/hr but less than 40 MMBtu/hr</p> <p>Fuel Type #1 = Natural gas</p> <p>NOx Emission Limitation = Title 30 TAC §§ 117.310(d)(3) and 117.310(a)(8)</p> <p>Diluent CEMS = The process heater does not use a carbon dioxide CEMS to monitor diluent.</p> <p>NOx Emission Limit Basis = Emission limit basis is not a rolling 30-day average or a block one-hour average</p> <p>NOx Reduction = No NO_x reduction</p> <p>NOx Monitoring System = Maximum emission rate testing [in accordance with 30 TAC § 117.8000]</p> <p>Fuel Flow Monitoring = Fuel flow is monitored with a totalizing fuel flow meter per 30 TAC §§ 117.140(a), 117.340(a) or 117.440(a).</p> <p>CO Emission Limitation = Title 30 TAC § 117.310(c)(1) 400 ppmv option</p> <p>CO Monitoring System = Emissions are monitored using method other than CEMS or PEMS.</p>	
OC5U5B01	30 TAC Chapter 117, Subchapter B	R7ICI-01	<p>Unit Type = Other industrial, commercial, or institutional boiler.</p> <p>Maximum Rated Capacity = MRC is greater than or equal to 40 MMBtu/hr but less than 100 MMBtu/hr.</p> <p>Fuel Type #1 = Natural gas.</p> <p>Annual Heat Input = Annual heat input is greater than 2.8(10¹¹) Btu/yr, based on rolling 12-month average.</p> <p>NOx Emission Limitation = Title 30 TAC § 117.310(d)(3) [relating to mass emissions cap and trade in 30 TAC Chapter 101, Subchapter H, Division 3 and Emission Specifications for Attainment Demonstration].</p> <p>EGF System Cap Unit = The unit is not used as an electric generating facility to generate electricity for sale to the electric grid.</p>	

Unit ID	Regulation	Index Number	Basis of Determination*	Changes and Exceptions to DSS**
			<p>NOx Emission Limit Average = Comply with the applicable emission limit in pounds/hour on a using block one-hour average.</p> <p>NOx Reductions = No NO_x reduction.</p> <p>NOx Monitoring System = Maximum emission rate testing.</p> <p>Fuel Flow Monitoring = Fuel flow is monitored with a totalizing fuel flow meter per 30 TAC §§ 117.140(a), 117.340(a) or 117.440(a).</p> <p>CO Emission Limitation = Title 30 TAC § 117.310(c)(1) 400 ppmv option.</p> <p>CO Monitoring System = Monitored by method other than CEMS or PEMS.</p>	
OC5U5B01	40 CFR Part 60, Subpart Dc	60Dc-01	<p>Construction/Modification Date = After June 9, 1989 but on or before February 28, 2005.</p> <p>Maximum Design Heat Input Capacity = Maximum design heat input capacity is greater than or equal to 10 MMBtu/hr (2.9 MW) but less than or equal to 100 MMBtu (29 MW).</p> <p>Applicability = Unit is not subject to other 40 CFR Part 60 subparts</p> <p>Heat Input Capacity = Heat input capacity is greater than 75 MMBtu/hr (22 MW).</p> <p>D-Series Fuel Type = Natural gas.</p> <p>ACF Option - SO₂ = Other ACF or no ACF.</p> <p>ACF Option - PM = Other ACF or no ACF.</p> <p>30% Coal Duct Burner = The facility does not combust coal in a duct burner as part of a combined cycle system; or more than 30% of the heat is from combustion of coal and less than 70% is from exhaust gases entering the duct burner.</p> <p>PM Monitoring Type = No particulate monitoring because there is no applicable PM emission limit</p> <p>SO₂ Inlet Monitoring Type = No SO₂ monitoring because there is no applicable SO₂ emission limit</p> <p>SO₂ Outlet Monitoring Type = No SO₂ monitoring because there is no applicable SO₂ emission limit</p> <p>Technology Type = No emerging or conventional technology is used to reduce or control SO₂ emissions</p>	
OC5U5B02	30 TAC Chapter 117, Subchapter B	R7ICI-01	<p>Unit Type = Other industrial, commercial, or institutional boiler.</p> <p>Maximum Rated Capacity = MRC is greater than or equal to 40 MMBtu/hr but less than 100 MMBtu/hr.</p> <p>Fuel Type #1 = Natural gas.</p> <p>Annual Heat Input = Annual heat input is greater than 2.8(10¹¹) Btu/yr, based on rolling 12-month average.</p>	

Unit ID	Regulation	Index Number	Basis of Determination*	Changes and Exceptions to DSS**
			<p>NOx Emission Limitation = Title 30 TAC § 117.310(d)(3) [relating to mass emissions cap and trade in 30 TAC Chapter 101, Subchapter H, Division 3 and Emission Specifications for Attainment Demonstration].</p> <p>EGF System Cap Unit = The unit is not used as an electric generating facility to generate electricity for sale to the electric grid.</p> <p>NOx Emission Limit Average = Comply with the applicable emission limit in pounds/hour on a using block one-hour average.</p> <p>NOx Reductions = No NO_x reduction.</p> <p>NOx Monitoring System = Maximum emission rate testing.</p> <p>Fuel Flow Monitoring = Fuel flow is monitored with a totalizing fuel flow meter per 30 TAC §§ 117.140(a), 117.340(a) or 117.440(a).</p> <p>CO Emission Limitation = Title 30 TAC § 117.310(c)(1) 400 ppmv option.</p> <p>CO Monitoring System = Monitored by method other than CEMS or PEMS.</p>	
OC5U5B02	40 CFR Part 60, Subpart Dc	60Dc-01	<p>Construction/Modification Date = After June 9, 1989 but on or before February 28, 2005.</p> <p>Maximum Design Heat Input Capacity = Maximum design heat input capacity is greater than or equal to 10 MMBtu/hr (2.9 MW) but less than or equal to 100 MMBtu (29 MW).</p> <p>Applicability = Unit is not subject to other 40 CFR Part 60 subparts</p> <p>Heat Input Capacity = Heat input capacity is greater than 75 MMBtu/hr (22 MW).</p> <p>D-Series Fuel Type = Natural gas.</p> <p>ACF Option - SO₂ = Other ACF or no ACF.</p> <p>ACF Option - PM = Other ACF or no ACF.</p> <p>30% Coal Duct Burner = The facility does not combust coal in a duct burner as part of a combined cycle system; or more than 30% of the heat is from combustion of coal and less than 70% is from exhaust gases entering the duct burner.</p> <p>PM Monitoring Type = No particulate monitoring because there is no applicable PM emission limit</p> <p>SO₂ Inlet Monitoring Type = No SO₂ monitoring because there is no applicable SO₂ emission limit</p> <p>SO₂ Outlet Monitoring Type = No SO₂ monitoring because there is no applicable SO₂ emission limit</p> <p>Technology Type = No emerging or conventional technology is used to reduce or control SO₂ emissions</p>	
OC5U5B401	30 TAC Chapter 117, Subchapter B	R7ICI-01	<p>Unit Type = Industrial, commercial, or institutional boiler regulated as an existing facility by the EPA at 40 CFR Part 266, Subpart H, as was in effect on June 9, 1993.</p>	

Unit ID	Regulation	Index Number	Basis of Determination*	Changes and Exceptions to DSS**
			<p>Maximum Rated Capacity = MRC is greater than or equal to 40 MMBtu/hr but less than 100 MMBtu/hr.</p> <p>Fuel Type #1 = Natural gas.</p> <p>Annual Heat Input = Annual heat input is greater than 2.8(10¹¹) Btu/yr, based on rolling 12-month average.</p> <p>NOx Emission Limitation = Title 30 TAC § 117.310(d)(3) [relating to mass emissions cap and trade in 30 TAC Chapter 101, Subchapter H, Division 3 and Emission Specifications for Attainment Demonstration].</p> <p>EGF System Cap Unit = The unit is not used as an electric generating facility to generate electricity for sale to the electric grid.</p> <p>NOx Emission Limit Average = Comply with the applicable emission limit in pounds/hour on a using block one-hour average.</p> <p>NOx Reductions = No NO_x reduction.</p> <p>NOx Monitoring System = Continuous emissions monitoring system.</p> <p>Fuel Flow Monitoring = Fuel flow is monitored with a totalizing fuel flow meter per 30 TAC §§ 117.140(a), 117.340(a) or 117.440(a).</p>	
OC5U5B401	40 CFR Part 60, Subpart Dc	60Dc-01	<p>Construction/Modification Date = After June 9, 1989 but on or before February 28, 2005.</p> <p>Maximum Design Heat Input Capacity = Maximum design heat input capacity is greater than or equal to 10 MMBtu/hr (2.9 MW) but less than or equal to 100 MMBtu (29 MW).</p> <p>Applicability = Unit is not subject to other 40 CFR Part 60 subparts</p> <p>Heat Input Capacity = Heat input capacity is greater than or equal to 30 MMBtu/hr (8.7 MW) but less than or equal to 75 MMBtu/hr (22 MW).</p> <p>D-Series Fuel Type = Natural gas.</p> <p>ACF Option - SO₂ = Other ACF or no ACF.</p> <p>ACF Option - PM = Other ACF or no ACF.</p> <p>30% Coal Duct Burner = The facility does not combust coal in a duct burner as part of a combined cycle system; or more than 30% of the heat is from combustion of coal and less than 70% is from exhaust gases entering the duct burner.</p> <p>PM Monitoring Type = No particulate monitoring because there is no applicable PM emission limit</p> <p>SO₂ Inlet Monitoring Type = No SO₂ monitoring because there is no applicable SO₂ emission limit</p> <p>SO₂ Outlet Monitoring Type = No SO₂ monitoring because there is no applicable SO₂ emission limit</p> <p>Technology Type = No emerging or conventional technology is used to reduce or control SO₂ emissions</p>	

Unit ID	Regulation	Index Number	Basis of Determination*	Changes and Exceptions to DSS**
OC5U5B402	30 TAC Chapter 117, Subchapter B	R7ICI-01	<p>Unit Type = Industrial, commercial, or institutional boiler regulated as an existing facility by the EPA at 40 CFR Part 266, Subpart H, as was in effect on June 9, 1993.</p> <p>Maximum Rated Capacity = MRC is greater than or equal to 40 MMBtu/hr but less than 100 MMBtu/hr.</p> <p>Fuel Type #1 = Natural gas.</p> <p>Annual Heat Input = Annual heat input is greater than 2.8(10¹¹) Btu/yr, based on rolling 12-month average.</p> <p>NOx Emission Limitation = Title 30 TAC § 117.310(d)(3) [relating to mass emissions cap and trade in 30 TAC Chapter 101, Subchapter H, Division 3 and Emission Specifications for Attainment Demonstration].</p> <p>EGF System Cap Unit = The unit is not used as an electric generating facility to generate electricity for sale to the electric grid.</p> <p>NOx Emission Limit Average = Comply with the applicable emission limit in pounds/hour on a using block one-hour average.</p> <p>NOx Reductions = No NO_x reduction.</p> <p>NOx Monitoring System = Continuous emissions monitoring system.</p> <p>Fuel Flow Monitoring = Fuel flow is monitored with a totalizing fuel flow meter per 30 TAC §§ 117.140(a), 117.340(a) or 117.440(a).</p>	
OC5U5B402	40 CFR Part 60, Subpart Dc	60Dc-01	<p>Construction/Modification Date = After June 9, 1989 but on or before February 28, 2005.</p> <p>Maximum Design Heat Input Capacity = Maximum design heat input capacity is greater than or equal to 10 MMBtu/hr (2.9 MW) but less than or equal to 100 MMBtu (29 MW).</p> <p>Applicability = Unit is not subject to other 40 CFR Part 60 subparts</p> <p>Heat Input Capacity = Heat input capacity is greater than or equal to 30 MMBtu/hr (8.7 MW) but less than or equal to 75 MMBtu/hr (22 MW).</p> <p>D-Series Fuel Type = Natural gas.</p> <p>ACF Option - SO₂ = Other ACF or no ACF.</p> <p>ACF Option - PM = Other ACF or no ACF.</p> <p>30% Coal Duct Burner = The facility does not combust coal in a duct burner as part of a combined cycle system; or more than 30% of the heat is from combustion of coal and less than 70% is from exhaust gases entering the duct burner.</p> <p>PM Monitoring Type = No particulate monitoring because there is no applicable PM emission limit</p> <p>SO₂ Inlet Monitoring Type = No SO₂ monitoring because there is no applicable SO₂ emission limit</p> <p>SO₂ Outlet Monitoring Type = No SO₂ monitoring because there is no applicable SO₂ emission limit</p>	

Unit ID	Regulation	Index Number	Basis of Determination*	Changes and Exceptions to DSS**
			Technology Type = No emerging or conventional technology is used to reduce or control SO2 emissions	
OC5U5H206	30 TAC Chapter 117, Subchapter B	R7ICI-01	<p>Unit Type = Other industrial, commercial, or institutional boiler.</p> <p>Maximum Rated Capacity = MRC is greater than 2 MMBtu/hr but less than 40 MMBtu/hr.</p> <p>Fuel Type #1 = Natural gas.</p> <p>NOx Emission Limitation = Title 30 TAC § 117.310(d)(3) [relating to mass emissions cap and trade in 30 TAC Chapter 101, Subchapter H, Division 3 and Emission Specifications for Attainment Demonstration].</p> <p>EGF System Cap Unit = The unit is not used as an electric generating facility to generate electricity for sale to the electric grid.</p> <p>NOx Emission Limit Average = Other emission limit basis.</p> <p>NOx Reductions = No NO_x reduction.</p> <p>NOx Monitoring System = Maximum emission rate testing.</p> <p>Fuel Flow Monitoring = Fuel flow is monitored with a totalizing fuel flow meter per 30 TAC §§ 117.140(a), 117.340(a) or 117.440(a).</p> <p>CO Emission Limitation = Title 30 TAC § 117.310(c)(1) 400 ppmv option.</p> <p>CO Monitoring System = Monitored by method other than CEMS or PEMS.</p>	
OC5U5H206	40 CFR Part 60, Subpart Dc	60Dc-01	<p>Construction/Modification Date = After June 9, 1989 but on or before February 28, 2005.</p> <p>Maximum Design Heat Input Capacity = Maximum design heat input capacity is greater than or equal to 10 MMBtu/hr (2.9 MW) but less than or equal to 100 MMBtu (29 MW).</p> <p>Applicability = Unit is not subject to other 40 CFR Part 60 subparts</p> <p>Heat Input Capacity = Heat input capacity is greater than 10 MMBtu/hr (2.9 MW) but less than 30 MMBtu/hr (8.7 MW).</p> <p>D-Series Fuel Type = Natural gas.</p> <p>ACF Option - SO2 = Other ACF or no ACF.</p> <p>ACF Option - PM = Other ACF or no ACF.</p> <p>30% Coal Duct Burner = The facility does not combust coal in a duct burner as part of a combined cycle system; or more than 30% of the heat is from combustion of coal and less than 70% is from exhaust gases entering the duct burner.</p> <p>PM Monitoring Type = No particulate monitoring because there is no applicable PM emission limit</p> <p>SO2 Inlet Monitoring Type = No SO2 monitoring because there is no applicable SO2 emission limit</p> <p>SO2 Outlet Monitoring Type = No SO2 monitoring because there is no applicable SO2 emission limit</p>	

Unit ID	Regulation	Index Number	Basis of Determination*	Changes and Exceptions to DSS**
			Technology Type = No emerging or conventional technology is used to reduce or control SO2 emissions	
OC5U5H207	30 TAC Chapter 117, Subchapter B	R7ICI-01	<p>Unit Type = Other industrial, commercial, or institutional boiler.</p> <p>Maximum Rated Capacity = MRC is greater than 2 MMBtu/hr but less than 40 MMBtu/hr.</p> <p>Fuel Type #1 = Natural gas.</p> <p>NOx Emission Limitation = Title 30 TAC § 117.310(d)(3) [relating to mass emissions cap and trade in 30 TAC Chapter 101, Subchapter H, Division 3 and Emission Specifications for Attainment Demonstration].</p> <p>EGF System Cap Unit = The unit is not used as an electric generating facility to generate electricity for sale to the electric grid.</p> <p>NOx Emission Limit Average = Other emission limit basis.</p> <p>NOx Reductions = No NO_x reduction.</p> <p>NOx Monitoring System = Maximum emission rate testing.</p> <p>Fuel Flow Monitoring = Fuel flow is monitored with a totalizing fuel flow meter per 30 TAC §§ 117.140(a), 117.340(a) or 117.440(a).</p> <p>CO Emission Limitation = Title 30 TAC § 117.310(c)(1) 400 ppmv option.</p> <p>CO Monitoring System = Monitored by method other than CEMS or PEMS.</p>	
OC5U5H207	40 CFR Part 60, Subpart Dc	60Dc-01	<p>Construction/Modification Date = After June 9, 1989 but on or before February 28, 2005.</p> <p>Maximum Design Heat Input Capacity = Maximum design heat input capacity is greater than or equal to 10 MMBtu/hr (2.9 MW) but less than or equal to 100 MMBtu (29 MW).</p> <p>Applicability = Unit is not subject to other 40 CFR Part 60 subparts</p> <p>Heat Input Capacity = Heat input capacity is greater than 10 MMBtu/hr (2.9 MW) but less than 30 MMBtu/hr (8.7 MW).</p> <p>D-Series Fuel Type = Natural gas.</p> <p>ACF Option - SO2 = Other ACF or no ACF.</p> <p>ACF Option - PM = Other ACF or no ACF.</p> <p>30% Coal Duct Burner = The facility does not combust coal in a duct burner as part of a combined cycle system; or more than 30% of the heat is from combustion of coal and less than 70% is from exhaust gases entering the duct burner.</p> <p>PM Monitoring Type = No particulate monitoring because there is no applicable PM emission limit</p> <p>SO2 Inlet Monitoring Type = No SO2 monitoring because there is no applicable SO2 emission limit</p> <p>SO2 Outlet Monitoring Type = No SO2 monitoring because there is no applicable SO2 emission limit</p>	

Unit ID	Regulation	Index Number	Basis of Determination*	Changes and Exceptions to DSS**
			Technology Type = No emerging or conventional technology is used to reduce or control SO2 emissions	
OC5U5H208	40 CFR Part 60, Subpart Dc	60Dc-01	<p>Construction/Modification Date = After June 9, 1989 but on or before February 28, 2005.</p> <p>Maximum Design Heat Input Capacity = Maximum design heat input capacity is greater than or equal to 10 MMBtu/hr (2.9 MW) but less than or equal to 100 MMBtu (29 MW).</p> <p>Applicability = Unit is not subject to other 40 CFR Part 60 subparts</p> <p>Heat Input Capacity = Heat input capacity is greater than 10 MMBtu/hr (2.9 MW) but less than 30 MMBtu/hr (8.7 MW).</p> <p>D-Series Fuel Type = Natural gas.</p> <p>ACF Option - SO2 = Other ACF or no ACF.</p> <p>ACF Option - PM = Other ACF or no ACF.</p> <p>30% Coal Duct Burner = The facility does not combust coal in a duct burner as part of a combined cycle system; or more than 30% of the heat is from combustion of coal and less than 70% is from exhaust gases entering the duct burner.</p> <p>PM Monitoring Type = No particulate monitoring because there is no applicable PM emission limit</p> <p>SO2 Inlet Monitoring Type = No SO2 monitoring because there is no applicable SO2 emission limit</p> <p>SO2 Outlet Monitoring Type = No SO2 monitoring because there is no applicable SO2 emission limit</p> <p>Technology Type = No emerging or conventional technology is used to reduce or control SO2 emissions</p>	
OC5U5H209	40 CFR Part 60, Subpart Dc	60Dc-01	<p>Construction/Modification Date = After June 9, 1989 but on or before February 28, 2005.</p> <p>Maximum Design Heat Input Capacity = Maximum design heat input capacity is greater than or equal to 10 MMBtu/hr (2.9 MW) but less than or equal to 100 MMBtu (29 MW).</p> <p>Applicability = Unit is not subject to other 40 CFR Part 60 subparts</p> <p>Heat Input Capacity = Heat input capacity is greater than 10 MMBtu/hr (2.9 MW) but less than 30 MMBtu/hr (8.7 MW).</p> <p>D-Series Fuel Type = Natural gas.</p> <p>ACF Option - SO2 = Other ACF or no ACF.</p> <p>ACF Option - PM = Other ACF or no ACF.</p> <p>30% Coal Duct Burner = The facility does not combust coal in a duct burner as part of a combined cycle system; or more than 30% of the heat is from combustion of coal and less than 70% is from exhaust gases entering the duct burner.</p>	

Unit ID	Regulation	Index Number	Basis of Determination*	Changes and Exceptions to DSS**
			PM Monitoring Type = No particulate monitoring because there is no applicable PM emission limit SO2 Inlet Monitoring Type = No SO2 monitoring because there is no applicable SO2 emission limit SO2 Outlet Monitoring Type = No SO2 monitoring because there is no applicable SO2 emission limit Technology Type = No emerging or conventional technology is used to reduce or control SO2 emissions	
A40ECFU2	30 TAC Chapter 115, HRVOC Fugitive Emissions	R5780-ALL	SOP Index No. = Owner/Operator assumes HRVOC fugitive control requirements for all components subject to 30 TAC Chapter 115, Subchapter H, Division 3 with no alternate control or control device.	
A40ECFU2	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	R5352-ALL	SOP/GOP Index No. = Owner/Operator assumes VOC fugitive control requirements for all components subject to 30 TAC Chapter 115, Subchapter D, Division 3 with no alternate control or control device.	
A40ECFU2	40 CFR Part 63, Subpart H	63H-ALL	SOP Index No. = Owner/Operator assumes fugitive control requirements for all components in VOC or VHAP service subject to 40 CFR Part 63, Subpart H with no alternated control or control device.	
A50ECFU3	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	R5352-ALL	SOP/GOP Index No. = Owner/Operator assumes VOC fugitive control requirements for all components subject to 30 TAC Chapter 115, Subchapter D, Division 3 with no alternate control or control device.	
A50ECFU3	40 CFR Part 63, Subpart H	63H-ALL	SOP Index No. = Owner/Operator assumes fugitive control requirements for all components in VOC or VHAP service subject to 40 CFR Part 63, Subpart H with no alternated control or control device.	
A70ECFU1	30 TAC Chapter 115, HRVOC Fugitive Emissions	R5780-ALL	SOP Index No. = Owner/Operator assumes HRVOC fugitive control requirements for all components subject to 30 TAC Chapter 115, Subchapter H, Division 3 with no alternate control or control device.	
A70ECFU1	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	R5352-ALL	SOP/GOP Index No. = Owner/Operator assumes VOC fugitive control requirements for all components subject to 30 TAC Chapter 115, Subchapter D, Division 3 with no alternate control or control device.	
A70ECFU1	40 CFR Part 63, Subpart H	63H-ALL	SOP Index No. = Owner/Operator assumes fugitive control requirements for all components in VOC or VHAP service subject to 40 CFR Part 63, Subpart H with no alternated control or control device.	

Unit ID	Regulation	Index Number	Basis of Determination*	Changes and Exceptions to DSS**
A70ECFU3A	30 TAC Chapter 115, HRVOC Fugitive Emissions	R5780-ALL	SOP Index No. = Owner/Operator assumes HRVOC fugitive control requirements for all components subject to 30 TAC Chapter 115, Subchapter H, Division 3 with no alternate control or control device.	
A70ECFU3A	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	R5352-ALL	SOP/GOP Index No. = Owner/Operator assumes VOC fugitive control requirements for all components subject to 30 TAC Chapter 115, Subchapter D, Division 3 with no alternate control or control device.	
A70ECFU3A	40 CFR Part 63, Subpart H	63H-ALL	SOP Index No. = Owner/Operator assumes fugitive control requirements for all components in VOC or VHAP service subject to 40 CFR Part 63, Subpart H with no alternated control or control device.	
A70ECFU3B	30 TAC Chapter 115, HRVOC Fugitive Emissions	R5780-ALL	SOP Index No. = Owner/Operator assumes HRVOC fugitive control requirements for all components subject to 30 TAC Chapter 115, Subchapter H, Division 3 with no alternate control or control device.	
A70ECFU3B	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	R5352-ALL	SOP/GOP Index No. = Owner/Operator assumes VOC fugitive control requirements for all components subject to 30 TAC Chapter 115, Subchapter D, Division 3 with no alternate control or control device.	
A70ECFU3B	40 CFR Part 60, Subpart VV	60VV-ALL	SOP Index No. = Owner or operator assumes fugitive unit control requirements for all components in VOC service subject to 40 CFR Part 60, Subpart VV with no alternate control or control devices.	
A70ECFU3B	40 CFR Part 63, Subpart EEEE	63EEEE-01	Component Service Hours = Pumps, valves or sampling connections at the Organic Loading Distribution Facility operate in organic HAP service 300 hours/yr or more.	
OC1U1FU2	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	R5352-ALL	SOP/GOP Index No. = Owner/Operator assumes VOC fugitive control requirements for all components subject to 30 TAC Chapter 115, Subchapter D, Division 3 with no alternate control or control device.	
OC1U1FU2	40 CFR Part 63, Subpart H	63H-ALL	SOP Index No. = Owner/Operator assumes fugitive control requirements for all components in VOC or VHAP service subject to 40 CFR Part 63, Subpart H with no alternated control or control device.	
OC5U5FU1	30 TAC Chapter 115, HRVOC Fugitive Emissions	R5780-ALL	SOP Index No. = Owner/Operator assumes HRVOC fugitive control requirements for all components subject to 30 TAC Chapter 115, Subchapter H, Division 3 with no alternate control or control device.	

Unit ID	Regulation	Index Number	Basis of Determination*	Changes and Exceptions to DSS**
OC5U5FU1	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	R5352-ALL	SOP/GOP Index No. = Owner/Operator assumes VOC fugitive control requirements for all components subject to 30 TAC Chapter 115, Subchapter D, Division 3 with no alternate control or control device.	
OC5U5FU1	40 CFR Part 63, Subpart H	63H-ALL	SOP Index No. = Owner/Operator assumes fugitive control requirements for all components in VOC or VHAP service subject to 40 CFR Part 63, Subpart H with no alternated control or control device.	
OC5U5FU2	30 TAC Chapter 115, HRVOC Fugitive Emissions	R5780-ALL	SOP Index No. = Owner/Operator assumes HRVOC fugitive control requirements for all components subject to 30 TAC Chapter 115, Subchapter H, Division 3 with no alternate control or control device.	
OC5U5FU2	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	R5352-ALL	SOP/GOP Index No. = Owner/Operator assumes VOC fugitive control requirements for all components subject to 30 TAC Chapter 115, Subchapter D, Division 3 with no alternate control or control device.	
OC5U5FU2	40 CFR Part 63, Subpart H	63H-ALL	SOP Index No. = Owner/Operator assumes fugitive control requirements for all components in VOC or VHAP service subject to 40 CFR Part 63, Subpart H with no alternated control or control device.	
OC5U5FU3	30 TAC Chapter 115, HRVOC Fugitive Emissions	R5780-ALL	SOP Index No. = Owner/Operator assumes HRVOC fugitive control requirements for all components subject to 30 TAC Chapter 115, Subchapter H, Division 3 with no alternate control or control device.	
OC5U5FU3	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	R5352-ALL	SOP/GOP Index No. = Owner/Operator assumes VOC fugitive control requirements for all components subject to 30 TAC Chapter 115, Subchapter D, Division 3 with no alternate control or control device.	
OC5U5FU3	40 CFR Part 63, Subpart H	63H-ALL	SOP Index No. = Owner/Operator assumes fugitive control requirements for all components in VOC or VHAP service subject to 40 CFR Part 63, Subpart H with no alternated control or control device.	
OC5U5FU4A	30 TAC Chapter 115, HRVOC Fugitive Emissions	R5780-ALL	SOP Index No. = Owner/Operator assumes HRVOC fugitive control requirements for all components subject to 30 TAC Chapter 115, Subchapter H, Division 3 with no alternate control or control device.	
OC5U5FU4A	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	R5352-ALL	SOP/GOP Index No. = Owner/Operator assumes VOC fugitive control requirements for all components subject to 30 TAC Chapter 115, Subchapter D, Division 3 with no alternate control or control device.	

Unit ID	Regulation	Index Number	Basis of Determination*	Changes and Exceptions to DSS**
OC5U5FU4A	40 CFR Part 63, Subpart H	63H-ALL	SOP Index No. = Owner/Operator assumes fugitive control requirements for all components in VOC or VHAP service subject to 40 CFR Part 63, Subpart H with no alternated control or control device.	
OC5U5FU4B	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	R5352-ALL	SOP/GOP Index No. = Owner/Operator assumes VOC fugitive control requirements for all components subject to 30 TAC Chapter 115, Subchapter D, Division 3 with no alternate control or control device.	
OC5U5FU4B	40 CFR Part 60, Subpart VV	60VV-ALL	SOP Index No. = Owner or operator assumes fugitive unit control requirements for all components in VOC service subject to 40 CFR Part 60, Subpart VV with no alternate control or control devices.	
OC5U5FU4B	40 CFR Part 63, Subpart EEEE	63EEEE-01	Component Service Hours = Pumps, valves or sampling connections at the Organic Loading Distribution Facility operate in organic HAP service 300 hours/yr or more.	
OC5U5FU5	30 TAC Chapter 115, HRVOC Fugitive Emissions	R5780-ALL	SOP Index No. = Owner/Operator assumes HRVOC fugitive control requirements for all components subject to 30 TAC Chapter 115, Subchapter H, Division 3 with no alternate control or control device.	
OC5U5FU5	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	R5352-ALL	SOP/GOP Index No. = Owner/Operator assumes VOC fugitive control requirements for all components subject to 30 TAC Chapter 115, Subchapter D, Division 3 with no alternate control or control device.	
OC5U5FU5	40 CFR Part 63, Subpart H	63H-ALL	SOP Index No. = Owner/Operator assumes fugitive control requirements for all components in VOC or VHAP service subject to 40 CFR Part 63, Subpart H with no alternated control or control device.	
OC5U5FU6	30 TAC Chapter 115, HRVOC Fugitive Emissions	R5780-ALL	SOP Index No. = Owner/Operator assumes HRVOC fugitive control requirements for all components subject to 30 TAC Chapter 115, Subchapter H, Division 3 with no alternate control or control device.	
OC5U5FU6	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	R5352-ALL	SOP/GOP Index No. = Owner/Operator assumes VOC fugitive control requirements for all components subject to 30 TAC Chapter 115, Subchapter D, Division 3 with no alternate control or control device.	
OC5U5FU6	40 CFR Part 63, Subpart H	63H-ALL	SOP Index No. = Owner/Operator assumes fugitive control requirements for all components in VOC or VHAP service subject to 40 CFR Part 63, Subpart H with no alternated control or control device.	

Unit ID	Regulation	Index Number	Basis of Determination*	Changes and Exceptions to DSS**
OC5U5FU7A	30 TAC Chapter 115, HRVOC Fugitive Emissions	R5780-ALL	SOP Index No. = Owner/Operator assumes HRVOC fugitive control requirements for all components subject to 30 TAC Chapter 115, Subchapter H, Division 3 with no alternate control or control device.	
OC5U5FU7A	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	R5352-ALL	SOP/GOP Index No. = Owner/Operator assumes VOC fugitive control requirements for all components subject to 30 TAC Chapter 115, Subchapter D, Division 3 with no alternate control or control device.	
OC5U5FU7A	40 CFR Part 63, Subpart H	63H-ALL	SOP Index No. = Owner/Operator assumes fugitive control requirements for all components in VOC or VHAP service subject to 40 CFR Part 63, Subpart H with no alternated control or control device.	
OC5U5FU7B	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	R5352-ALL	SOP/GOP Index No. = Owner/Operator assumes VOC fugitive control requirements for all components subject to 30 TAC Chapter 115, Subchapter D, Division 3 with no alternate control or control device.	
OC5U5FU7B	40 CFR Part 60, Subpart VV	60VV-ALL	SOP Index No. = Owner or operator assumes fugitive unit control requirements for all components in VOC service subject to 40 CFR Part 60, Subpart VV with no alternate control or control devices.	
OC5U5FU7B	40 CFR Part 63, Subpart EEEE	63EEEE-01	Component Service Hours = Pumps, valves or sampling connections at the Organic Loading Distribution Facility operate in organic HAP service 300 hours/yr or more.	
OC9U1FU4A	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	R5352-ALL	SOP/GOP Index No. = Owner/Operator assumes VOC fugitive control requirements for all components subject to 30 TAC Chapter 115, Subchapter D, Division 3 with no alternate control or control device.	
OC9U1FU4A	40 CFR Part 63, Subpart H	63H-ALL	SOP Index No. = Owner/Operator assumes fugitive control requirements for all components in VOC or VHAP service subject to 40 CFR Part 63, Subpart H with no alternated control or control device.	
OC9U1FU4B	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	R5352-ALL	SOP/GOP Index No. = Owner/Operator assumes VOC fugitive control requirements for all components subject to 30 TAC Chapter 115, Subchapter D, Division 3 with no alternate control or control device.	
OC9U1FU4B	40 CFR Part 60, Subpart VV	60VV-ALL	SOP Index No. = Owner or operator assumes fugitive unit control requirements for all components in VOC service subject to 40 CFR Part 60, Subpart VV with no alternate control or control devices.	
OC9U1FU4B	40 CFR Part 61, Subpart F	61F-01	RELIEF VALVES = NO	

Unit ID	Regulation	Index Number	Basis of Determination*	Changes and Exceptions to DSS**
			<p>LOADING AND UNLOADING = YES</p> <p>SLIP GAUGES = NO</p> <p>INPROCESS WASTEWATER STREAMS = NO</p> <p>ROTATING PUMPS = YES</p> <p>RECIPROCATING PUMPS = YES</p> <p>ROTATING COMPRESSORS = NO</p> <p>RECIPROCATING COMPRESSORS = NO</p> <p>AGITATOR = NO</p> <p>Sampling Equipment = Fugitive unit does not contain sampling equipment.</p> <p>VALVES = VALVE OTHER THAN RELIEF VALVE OR VALVE ON OPEN-ENDED LINE</p> <p>APPROVED LEAK DETECTION PLAN = PROCESS UNIT IS USING A VINYL CHLORIDE MONITORING SYSTEM FOR LEAK DETECTION OPERATING UNDER A PROGRAM APPROVED BY THE EPA ADMINISTRATOR</p> <p>OPEN-ENDED VALVES OR LINES = FUGITIVE UNIT DOES NOT CONTAIN OPEN-ENDED VALVES OR LINES</p> <p>MULTIPLE PROCESS SERVICE LINE = NO OPEN-ENDED VALVES OR LINES ARE LOCATED ON MULTIPLE PROCESS SERVICE LINES, OPERATING IN VINYL CHLORIDE SERVICE LESS THAN 10% OF THE TIME AND ARE ADDRESSED IN THE MONITORING PLAN UNDER 40 CFR § 61.65(B)(8)(I)</p> <p>FLARE = NO</p> <p>ENCLOSED COMBUSTION DEVICE = NO ENCLOSED COMBUSTION DEVICE IS USED FOR CONTROL</p> <p>VAPOR RECOVERY SYSTEM = NO VAPOR RECOVERY SYSTEM IS USED FOR CONTROL</p>	
OC9U1FU4B	40 CFR Part 63, Subpart EEEE	63EEEE-01	Component Service Hours = Pumps, valves or sampling connections at the Organic Loading Distribution Facility operate in organic HAP service 300 hours/yr or more.	
OC5U5CT1	30 TAC Chapter 115, HRVOC Cooling Towers	R5760-01	<p>Cooling Tower Heat Exchange System Exemptions = The cooling tower heat exchange system does not qualify for an exemption.</p> <p>Alternative Monitoring = Complying with the specified monitoring in 30 TAC § 115.764.</p> <p>Modified Monitoring = NOT USING MINOR MODIFICATIONS TO THE MONITORING AND TESTING METHODS IN 30 TAC § 115.764.</p> <p>Jacketed Reactor = The cooling tower heat exchange system is not in dedicated service to a jacketed reactor.</p> <p>Design Capacity = Design capacity to circulate 8000 gpm or greater.</p>	

Unit ID	Regulation	Index Number	Basis of Determination*	Changes and Exceptions to DSS**
			<p>Finite Volume System = The cooling tower heat exchange system is complying with the requirements in § 115.764(a).</p> <p>Flow Monitoring/Testing Method = Choosing to use a continuous flow monitor on each inlet of each cooling tower in accordance with § 115.764(a)(1), (b)(1), or (h)(1).</p> <p>Total Strippable VOC = The cooling tower heat exchange system is complying with the requirements of § 115.764(a).</p> <p>On-Line Monitor = A continuous on-line monitor capable of providing total HRVOC and speciated HRVOCs in ppbw is being used.</p>	
OC5U5CT2	30 TAC Chapter 115, HRVOC Cooling Towers	R5760-01	<p>Cooling Tower Heat Exchange System Exemptions = The cooling tower heat exchange system does not qualify for an exemption.</p> <p>Alternative Monitoring = Complying with the specified monitoring in 30 TAC § 115.764.</p> <p>Modified Monitoring = NOT USING MINOR MODIFICATIONS TO THE MONITORING AND TESTING METHODS IN 30 TAC § 115.764.</p> <p>Jacketed Reactor = The cooling tower heat exchange system is not in dedicated service to a jacketed reactor.</p> <p>Design Capacity = Design capacity to circulate 8000 gpm or greater.</p> <p>Finite Volume System = The cooling tower heat exchange system is complying with the requirements in § 115.764(a).</p> <p>Flow Monitoring/Testing Method = Choosing to use a continuous flow monitor on each inlet of each cooling tower in accordance with § 115.764(a)(1), (b)(1), or (h)(1).</p> <p>Total Strippable VOC = The cooling tower heat exchange system is complying with the requirements of § 115.764(a).</p> <p>On-Line Monitor = A continuous on-line monitor capable of providing total HRVOC and speciated HRVOCs in ppbw is being used.</p>	
OC5U5ST130	30 TAC Chapter 115, Water Separation	R5131-01	<p>Alternate Control Requirement = The executive director (or the EPA Administrator) has not approved an ACR or exemption criteria in accordance with 30 TAC § 115.910.</p> <p>Exemption = Water separator does not qualify for exemption.</p> <p>Emission Control Option = Vapor recovery system which satisfies the provisions of 30 TAC § 115.131.</p> <p>Control Device = Direct flame incinerator.</p>	
A24ECLR1	40 CFR Part 63, Subpart G	63G-01	<p>Overlap = Title 40 CFR Part 63, Subpart G only</p> <p>Group 1 = The process vent meets the definition of a Group 1 process vent.</p> <p>Control Device = Boiler or process heater into which the process vent stream is introduced with the primary fuel or is used as the primary fuel.</p> <p>Halogenated = Vent stream is halogenated.</p>	

Unit ID	Regulation	Index Number	Basis of Determination*	Changes and Exceptions to DSS**
			<p>Halogen Reduction Device = The vent stream exiting the combustion device is ducted to a scrubber before it is discharged to the atmosphere.</p> <p>Installation Date = On or after 12/31/92</p> <p>Performance Test = A performance test was conducted for determining compliance with a regulation promulgated by the EPA using the same methods specified in Subpart G and either no process changes have been made, or the results reliably indicate compliance.</p> <p>Alternate Monitoring Parameters = The EPA Administrator has not approved alternate monitoring parameters or alternate monitoring parameters are not used.</p> <p>Continuous Monitoring = Complying with the continuous monitoring requirements of 40 CFR §§ 63.114, 63.117, and 63.118.</p> <p>By-pass Lines = The vent system contains by-pass lines that can divert the vent stream from the control device.</p> <p>Flow Indicator = By-pass line valve is secured with a car-seal or lock-and-key type configuration.</p>	
A24ECLR1	40 CFR Part 63, Subpart G	63G-02	<p>Overlap = Title 40 CFR Part 63, Subpart G only</p> <p>Group 1 = The process vent meets the definition of a Group 1 process vent.</p> <p>Control Device = Boiler or process heater into which the process vent stream is introduced with the primary fuel or is used as the primary fuel.</p> <p>Halogenated = Vent stream is halogenated.</p> <p>Halogen Reduction Device = The vent stream exiting the combustion device is ducted to a scrubber before it is discharged to the atmosphere.</p> <p>Installation Date = On or after 12/31/92</p> <p>Performance Test = A performance test was conducted for determining compliance with a regulation promulgated by the EPA using the same methods specified in Subpart G and either no process changes have been made, or the results reliably indicate compliance.</p> <p>Alternate Monitoring Parameters = The EPA Administrator has not approved alternate monitoring parameters or alternate monitoring parameters are not used.</p> <p>Continuous Monitoring = Complying with the continuous monitoring requirements of 40 CFR §§ 63.114, 63.117, and 63.118.</p> <p>By-pass Lines = The vent system contains by-pass lines that can divert the vent stream from the control device.</p> <p>Flow Indicator = By-pass line valve is secured with a car-seal or lock-and-key type configuration.</p>	
OC5U5B01	30 TAC Chapter 115, Vent Gas Controls	R5121-01	<p>Chapter 115 Division = The vent stream does not originate from a source for which another Division in 30 TAC Chapter 115 establishes a control requirement, emission specification, or exemption for that source.</p>	

Unit ID	Regulation	Index Number	Basis of Determination*	Changes and Exceptions to DSS**
			<p>Combustion Exhaust = The vent stream is not from a combustion unit exhaust or the combustion unit is used as a control device for a vent stream originating from a noncombustion source subject to 30 TAC Chapter 115, Subchapter B, Division 2.</p> <p>Vent Type = Vent gas stream originates from a synthetic organic chemical manufacturing industry reactor process or distillation operation, as defined in 30 TAC § 115.10.</p> <p>Alternate Control Requirement = Alternate control is not used.</p> <p>Control Device Type = Direct flame incinerator in which the vent gas stream is burned at a temperature or at least 1300° F (704 C).</p> <p>Total Design Capacity = Total design capacity is greater than or equal to 1,100 tons per year for all chemicals produced within that unit.</p> <p>Flow Rate or VOC Concentration = Flow rate is greater than or equal to 0.011 scm/min or the VOC concentration is greater than or equal to 500 ppmv.</p> <p>40 CFR 60 Subpart NNN Requirements = The distillation unit vent gas stream satisfies neither of the following requirements of 40 CFR Part 60, Subpart NNN: TRE index value is greater than 8.0; or TRE index value is greater than 1.0 without the use of VOC emission control devices.</p> <p>40 CFR 60 Subpart RRR Requirements = The reactor process vent gas stream satisfies neither of the following requirements of 40 CFR Part 60, Subpart RRR: TRE index value is greater than 8.0; or TRE index value is greater than 1.0 without the use of VOC emission control devices.</p>	
OC5U5B01	40 CFR Part 63, Subpart G	63G-01	<p>Overlap = Title 40 CFR Part 63, Subpart G only</p> <p>Group 1 = The process vent meets the definition of a Group 1 process vent.</p> <p>Electing Control = Electing to control the process vent to the levels required in 40 CFR § 63.113(a)(2) without calculating the TRE index value</p> <p>Control Device = Boiler or process heater into which the process vent stream is introduced with the primary fuel or is used as the primary fuel.</p> <p>Halogenated = Vent stream is halogenated.</p> <p>Halogen Reduction Device = The vent stream exiting the combustion device is ducted to a scrubber before it is discharged to the atmosphere.</p> <p>Installation Date = On or after 12/31/92</p> <p>Performance Test = No previous performance test was conducted.</p> <p>Alternate Monitoring Parameters = The EPA Administrator has not approved alternate monitoring parameters or alternate monitoring parameters are not used.</p> <p>Continuous Monitoring = Complying with the continuous monitoring requirements of 40 CFR §§ 63.114, 63.117, and 63.118.</p> <p>By-pass Lines = The vent system does not contain by-pass lines that can divert the vent stream from the control device.</p>	

Unit ID	Regulation	Index Number	Basis of Determination*	Changes and Exceptions to DSS**
OC5U5B02	30 TAC Chapter 115, Vent Gas Controls	R5121-01	<p>Chapter 115 Division = The vent stream does not originate from a source for which another Division in 30 TAC Chapter 115 establishes a control requirement, emission specification, or exemption for that source.</p> <p>Combustion Exhaust = The vent stream is not from a combustion unit exhaust or the combustion unit is used as a control device for a vent stream originating from a noncombustion source subject to 30 TAC Chapter 115, Subchapter B, Division 2.</p> <p>Vent Type = Vent gas stream originates from a synthetic organic chemical manufacturing industry reactor process or distillation operation, as defined in 30 TAC § 115.10.</p> <p>Alternate Control Requirement = Alternate control is not used.</p> <p>Control Device Type = Direct flame incinerator in which the vent gas stream is burned at a temperature or at least 1300° F (704 C).</p> <p>Total Design Capacity = Total design capacity is greater than or equal to 1,100 tons per year for all chemicals produced within that unit.</p> <p>Flow Rate or VOC Concentration = Flow rate is greater than or equal to 0.011 scm/min or the VOC concentration is greater than or equal to 500 ppmv.</p> <p>40 CFR 60 Subpart NNN Requirements = The distillation unit vent gas stream satisfies neither of the following requirements of 40 CFR Part 60, Subpart NNN: TRE index value is greater than 8.0; or TRE index value is greater than 1.0 without the use of VOC emission control devices.</p> <p>40 CFR 60 Subpart RRR Requirements = The reactor process vent gas stream satisfies neither of the following requirements of 40 CFR Part 60, Subpart RRR: TRE index value is greater than 8.0; or TRE index value is greater than 1.0 without the use of VOC emission control devices.</p>	
OC5U5B02	40 CFR Part 63, Subpart G	63G-01	<p>Overlap = Title 40 CFR Part 63, Subpart G only</p> <p>Group 1 = The process vent meets the definition of a Group 1 process vent.</p> <p>Electing Control = Electing to control the process vent to the levels required in 40 CFR § 63.113(a)(2) without calculating the TRE index value</p> <p>Control Device = Boiler or process heater into which the process vent stream is introduced with the primary fuel or is used as the primary fuel.</p> <p>Halogenated = Vent stream is halogenated.</p> <p>Halogen Reduction Device = The vent stream exiting the combustion device is ducted to a scrubber before it is discharged to the atmosphere.</p> <p>Installation Date = On or after 12/31/92</p> <p>Performance Test = No previous performance test was conducted.</p> <p>Alternate Monitoring Parameters = The EPA Administrator has not approved alternate monitoring parameters or alternate monitoring parameters are not used.</p>	

Unit ID	Regulation	Index Number	Basis of Determination*	Changes and Exceptions to DSS**
			<p>Continuous Monitoring = Complying with the continuous monitoring requirements of 40 CFR §§ 63.114, 63.117, and 63.118.</p> <p>By-pass Lines = The vent system does not contain by-pass lines that can divert the vent stream from the control device.</p>	
OC5U5B401	30 TAC Chapter 115, HRVOC Vent Gas	R5720-01	<p>HRVOC Concentration = The vent gas stream has a HRVOC concentration of at least 100 ppmv at some times.</p> <p>Max Flow Rate = The vent gas stream has a maximum potential flow rate greater than 100 dry standard cubic feet per hour (ft³/hr).</p> <p>Vent Gas Stream Control = Vent gas stream is controlled by a control device other than a flare.</p> <p>Alternative Monitoring = Not using alternative monitoring and testing methods.</p> <p>Minor Modification = Not using any minor modification to the monitoring and testing methods of the rule.</p> <p>Process Knowledge = Process knowledge and engineering calculations are used to determine HRVOC emissions during emission events and scheduled startup, shutdown, and maintenance activities.</p> <p>Waived Testing = The executive director has not waived testing for identical vents.</p> <p>Testing Requirements = Continuous emissions monitoring system in lieu of testing requirements in § 115.725(a).</p>	
OC5U5B401	30 TAC Chapter 115, Vent Gas Controls	R5121-01	<p>Chapter 115 Division = The vent stream does not originate from a source for which another Division in 30 TAC Chapter 115 establishes a control requirement, emission specification, or exemption for that source.</p> <p>Combustion Exhaust = The vent stream is not from a combustion unit exhaust or the combustion unit is used as a control device for a vent stream originating from a noncombustion source subject to 30 TAC Chapter 115, Subchapter B, Division 2.</p> <p>Vent Type = Vent gas stream originates from a synthetic organic chemical manufacturing industry reactor process or distillation operation, as defined in 30 TAC § 115.10.</p> <p>Alternate Control Requirement = Alternate control is not used.</p> <p>Control Device Type = Direct flame incinerator in which the vent gas stream is burned at a temperature or at least 1300° F (704 C).</p> <p>Total Design Capacity = Total design capacity is greater than or equal to 1,100 tons per year for all chemicals produced within that unit.</p> <p>Flow Rate or VOC Concentration = Flow rate is greater than or equal to 0.011 scm/min or the VOC concentration is greater than or equal to 500 ppmv.</p> <p>40 CFR 60 Subpart NNN Requirements = The distillation unit vent gas stream satisfies neither of the following requirements of 40 CFR Part 60,</p>	

Unit ID	Regulation	Index Number	Basis of Determination*	Changes and Exceptions to DSS**
			Subpart NNN: TRE index value is greater than 8.0; or TRE index value is greater than 1.0 without the use of VOC emission control devices.	
OC5U5B401	40 CFR Part 63, Subpart G	63G-01	<p>Overlap = Title 40 CFR Part 63, Subpart G only</p> <p>Group 1 = The process vent meets the definition of a Group 1 process vent.</p> <p>Electing Control = Electing to control the process vent to the levels required in 40 CFR § 63.113(a)(2) without calculating the TRE index value</p> <p>Control Device = Boiler or process heater into which the process vent stream is introduced with the primary fuel or is used as the primary fuel.</p> <p>Halogenated = Vent stream is halogenated.</p> <p>Halogen Reduction Device = The vent stream exiting the combustion device is ducted to a scrubber before it is discharged to the atmosphere.</p> <p>Installation Date = On or after 12/31/92</p> <p>Performance Test = No previous performance test was conducted.</p> <p>Alternate Monitoring Parameters = The EPA Administrator has not approved alternate monitoring parameters or alternate monitoring parameters are not used.</p> <p>Continuous Monitoring = Complying with the continuous monitoring requirements of 40 CFR §§ 63.114, 63.117, and 63.118.</p> <p>By-pass Lines = The vent system does not contain by-pass lines that can divert the vent stream from the control device.</p>	
OC5U5B402	30 TAC Chapter 115, HRVOC Vent Gas	R5720-01	<p>HRVOC Concentration = The vent gas stream has a HRVOC concentration of at least 100 ppmv at some times.</p> <p>Max Flow Rate = The vent gas stream has a maximum potential flow rate greater than 100 dry standard cubic feet per hour (ft³/hr).</p> <p>Vent Gas Stream Control = Vent gas stream is controlled by a control device other than a flare.</p> <p>Alternative Monitoring = Not using alternative monitoring and testing methods.</p> <p>Minor Modification = Not using any minor modification to the monitoring and testing methods of the rule.</p> <p>Process Knowledge = Process knowledge and engineering calculations are used to determine HRVOC emissions during emission events and scheduled startup, shutdown, and maintenance activities.</p> <p>Waived Testing = The executive director has not waived testing for identical vents.</p> <p>Testing Requirements = Continuous emissions monitoring system in lieu of testing requirements in § 115.725(a).</p>	

Unit ID	Regulation	Index Number	Basis of Determination*	Changes and Exceptions to DSS**
OC5U5B402	30 TAC Chapter 115, Vent Gas Controls	R5121-01	<p>Chapter 115 Division = The vent stream does not originate from a source for which another Division in 30 TAC Chapter 115 establishes a control requirement, emission specification, or exemption for that source.</p> <p>Combustion Exhaust = The vent stream is not from a combustion unit exhaust or the combustion unit is used as a control device for a vent stream originating from a noncombustion source subject to 30 TAC Chapter 115, Subchapter B, Division 2.</p> <p>Vent Type = Vent gas stream originates from a synthetic organic chemical manufacturing industry reactor process or distillation operation, as defined in 30 TAC § 115.10.</p> <p>Alternate Control Requirement = Alternate control is not used.</p> <p>Control Device Type = Direct flame incinerator in which the vent gas stream is burned at a temperature or at least 1300° F (704 C).</p> <p>Total Design Capacity = Total design capacity is greater than or equal to 1,100 tons per year for all chemicals produced within that unit.</p> <p>Flow Rate or VOC Concentration = Flow rate is greater than or equal to 0.011 scm/min or the VOC concentration is greater than or equal to 500 ppmv.</p> <p>40 CFR 60 Subpart NNN Requirements = The distillation unit vent gas stream satisfies neither of the following requirements of 40 CFR Part 60, Subpart NNN: TRE index value is greater than 8.0; or TRE index value is greater than 1.0 without the use of VOC emission control devices.</p> <p>40 CFR 60 Subpart RRR Requirements = The reactor process vent gas stream satisfies neither of the following requirements of 40 CFR Part 60, Subpart RRR: TRE index value is greater than 8.0; or TRE index value is greater than 1.0 without the use of VOC emission control devices.</p>	
OC5U5B402	40 CFR Part 63, Subpart G	63G-01	<p>Overlap = Title 40 CFR Part 63, Subpart G only</p> <p>Group 1 = The process vent meets the definition of a Group 1 process vent.</p> <p>Electing Control = Electing to control the process vent to the levels required in 40 CFR § 63.113(a)(2) without calculating the TRE index value</p> <p>Control Device = Boiler or process heater into which the process vent stream is introduced with the primary fuel or is used as the primary fuel.</p> <p>Halogenated = Vent stream is halogenated.</p> <p>Halogen Reduction Device = The vent stream exiting the combustion device is ducted to a scrubber before it is discharged to the atmosphere.</p> <p>Installation Date = On or after 12/31/92</p> <p>Performance Test = No previous performance test was conducted.</p> <p>Alternate Monitoring Parameters = The EPA Administrator has not approved alternate monitoring parameters or alternate monitoring parameters are not used.</p>	

Unit ID	Regulation	Index Number	Basis of Determination*	Changes and Exceptions to DSS**
			<p>Continuous Monitoring = Complying with the continuous monitoring requirements of 40 CFR §§ 63.114, 63.117, and 63.118.</p> <p>By-pass Lines = The vent system does not contain by-pass lines that can divert the vent stream from the control device.</p>	
OC5U5D497	40 CFR Part 63, Subpart GGGGG	63GGGGG-01	<p>Emissions = Total emissions of HAP from the vent are reduced by 95 percent by weight or more</p> <p>Uncontrolled Vent Streams = Uncontrolled vent streams are not included in the facility wide emission limit</p> <p>Control Device = Boiler or process heater</p> <p>Design Evaluation = Design evaluation is used to demonstrate initial control device compliance</p> <p>Bypass Device = No bypass device</p> <p>Continuous Emissions Monitoring System = A continuous emissions monitoring system is not used to monitor the control device</p> <p>CVSCD Continuous Compliance = The closed vent system is designed to operate with no detectable organic emissions, as specified in 40 CFR § 63.7928(b)(1)</p>	
OC5U5H206	30 TAC Chapter 111, Visible Emissions	R1111-01	<p>Alternate Opacity Limitation = Not complying with an alternate opacity limit under 30 TAC § 111.113.</p> <p>Vent Source = The source of the vent is not a steam generator fired by solid fossil fuel, oil or a mixture of oil and gas and is not a catalyst regenerator for a fluid bed catalytic cracking unit.</p> <p>Opacity Monitoring System = Optical instrument capable of measuring the opacity of emissions is not installed in the vent or optical instrumentation does not meet the requirements of § 111.111(a)(1)(D), or the vent stream does not qualify for the exemption in § 111.111(a)(3).</p> <p>Construction Date = After January 31, 1972</p> <p>Effluent Flow Rate = Effluent flow rate is less than 100,000 actual cubic feet per minute.</p>	
OC5U5H207	30 TAC Chapter 111, Visible Emissions	R1111-01	<p>Alternate Opacity Limitation = Not complying with an alternate opacity limit under 30 TAC § 111.113.</p> <p>Vent Source = The source of the vent is not a steam generator fired by solid fossil fuel, oil or a mixture of oil and gas and is not a catalyst regenerator for a fluid bed catalytic cracking unit.</p> <p>Opacity Monitoring System = Optical instrument capable of measuring the opacity of emissions is not installed in the vent or optical instrumentation does not meet the requirements of § 111.111(a)(1)(D), or the vent stream does not qualify for the exemption in § 111.111(a)(3).</p> <p>Construction Date = After January 31, 1972</p> <p>Effluent Flow Rate = Effluent flow rate is less than 100,000 actual cubic feet per minute.</p>	

Unit ID	Regulation	Index Number	Basis of Determination*	Changes and Exceptions to DSS**
OC5U5H208	30 TAC Chapter 111, Visible Emissions	R1111-01	<p>Alternate Opacity Limitation = Not complying with an alternate opacity limit under 30 TAC § 111.113.</p> <p>Vent Source = The source of the vent is not a steam generator fired by solid fossil fuel, oil or a mixture of oil and gas and is not a catalyst regenerator for a fluid bed catalytic cracking unit.</p> <p>Opacity Monitoring System = Optical instrument capable of measuring the opacity of emissions is not installed in the vent or optical instrumentation does not meet the requirements of § 111.111(a)(1)(D), or the vent stream does not qualify for the exemption in § 111.111(a)(3).</p> <p>Construction Date = After January 31, 1972</p> <p>Effluent Flow Rate = Effluent flow rate is less than 100,000 actual cubic feet per minute.</p>	
OC5U5H209	30 TAC Chapter 111, Visible Emissions	R1111-01	<p>Alternate Opacity Limitation = Not complying with an alternate opacity limit under 30 TAC § 111.113.</p> <p>Vent Source = The source of the vent is not a steam generator fired by solid fossil fuel, oil or a mixture of oil and gas and is not a catalyst regenerator for a fluid bed catalytic cracking unit.</p> <p>Opacity Monitoring System = Optical instrument capable of measuring the opacity of emissions is not installed in the vent or optical instrumentation does not meet the requirements of § 111.111(a)(1)(D), or the vent stream does not qualify for the exemption in § 111.111(a)(3).</p> <p>Construction Date = After January 31, 1972</p> <p>Effluent Flow Rate = Effluent flow rate is less than 100,000 actual cubic feet per minute.</p>	
OC5U5T498	40 CFR Part 63, Subpart GGGGG	63GGGGG-01	<p>Emissions = Total emissions of HAP from the vent are reduced by 95 percent by weight or more</p> <p>Uncontrolled Vent Streams = Uncontrolled vent streams are not included in the facility wide emission limit</p> <p>Control Device = Boiler or process heater</p> <p>Design Evaluation = Design evaluation is used to demonstrate initial control device compliance</p> <p>Bypass Device = No bypass device</p> <p>Continuous Emissions Monitoring System = A continuous emissions monitoring system is not used to monitor the control device</p> <p>CVSCD Continuous Compliance = The closed vent system is designed to operate with no detectable organic emissions, as specified in 40 CFR § 63.7928(b)(1)</p>	
OC5DGRS	30 TAC Chapter 115, Degreasing Processes	R5412-01	<p>Solvent Degreasing Machine Type = Cold solvent cleaning machine.</p> <p>Alternate Control Requirement = The TCEQ Executive Director has not approved an alternative control requirement as allowed under 30 TAC § 115.413 or not alternative has been requested.</p>	

Unit ID	Regulation	Index Number	Basis of Determination*	Changes and Exceptions to DSS**
			<p>Solvent Sprayed = A solvent is sprayed.</p> <p>Solvent Vapor Pressure = Solvent vapor pressure is less than or equal to 0.6 psia as measured at 100 degrees Fahrenheit.</p> <p>Solvent Heated = The solvent is not heated to a temperature greater than 120 degrees Fahrenheit</p> <p>Parts Larger than Drainage = No cleaned parts for which the machine is authorized to clean are larger than the internal drainage facility of the machine.</p> <p>Drainage Area = Area is greater than or equal to 16 square inches.</p> <p>Disposal in Enclosed Containers = Waste solvent is properly disposed of in enclosed containers.</p>	
PROU5EDC	40 CFR Part 61, Subpart F	61F-01	<p>Product Produced = Ethylene dichloride by reaction of oxygen and hydrogen chloride with ethylene.</p> <p>EEP = The EPA Administrator has not approved equivalent equipment or procedures.</p> <p>Oxychlorination Reactor = The process contains an oxychlorination reactor.</p> <p>Ethylene Dichloride Purification = The process contains equipment used in ethylene dichloride purification.</p> <p>Existing Source = The source is a new source.</p> <p>Initial Startup = The initial startup date of the new source was on or after the effective date.</p> <p>Reactor = The process includes a reactor.</p> <p>Stripper = The process does not include a stripper.</p> <p>Monomer Recovery System = The process does not include a monomer recovery system.</p> <p>Preceding Stripper = No mixing, weighing, or holding containers precede a stripper (or reactor if the process has no stripper).</p>	
PROU5VCM	40 CFR Part 61, Subpart F	61F-01	<p>Product Produced = Vinyl chloride by any process.</p> <p>EEP = The EPA Administrator has not approved equivalent equipment or procedures.</p> <p>Existing Source = The source is a new source.</p> <p>Initial Startup = The initial startup date of the new source was on or after the effective date.</p> <p>Reactor = The process includes a reactor.</p> <p>Stripper = The process does not include a stripper.</p> <p>Monomer Recovery System = The process does not include a monomer recovery system.</p>	

Unit ID	Regulation	Index Number	Basis of Determination*	Changes and Exceptions to DSS**
			Preceding Stripper = No mixing, weighing, or holding containers precede a stripper (or reactor if the process has no stripper).	
PROEDC	30 TAC Chapter 115, Subchapter E, Division 6	R5460-01	Exemptions = No exemption is being met. Alternate Control Requirement = Alternate control not used. Compliance Demonstration = Limiting VOC content of the cleaning solution to 0.42 lb VOC/gal of solution, as applied. Minor Modification = Using the methods in §115.468(a)(1)-(3).	
PROEDC	30 TAC Chapter 115, Subchapter E, Division 6	R5460-02	Exemptions = No exemption is being met. Alternate Control Requirement = Alternate control not used. Compliance Demonstration = Limiting the composite partial vapor pressure of the cleaning solution to 8.0 millimeters of mercury at 20 degrees Celsius (68 degrees Fahrenheit). Minor Modification = Using the methods in §115.468(a)(1)-(3).	
PROEDC	30 TAC Chapter 115, Subchapter E, Division 6	R5460-03	Exemptions = The solvent cleaning operation is subject to another division of Chapter 115 and VOC emissions are controlled in accordance with that division.	
PROU5	30 TAC Chapter 115, Subchapter E, Division 6	R5460-01	Exemptions = No exemption is being met. Alternate Control Requirement = Alternate control not used. Compliance Demonstration = Limiting VOC content of the cleaning solution to 0.42 lb VOC/gal of solution, as applied. Minor Modification = Using the methods in §115.468(a)(1)-(3).	
PROU5	30 TAC Chapter 115, Subchapter E, Division 6	R5460-02	Exemptions = No exemption is being met. Alternate Control Requirement = Alternate control not used. Compliance Demonstration = Limiting the composite partial vapor pressure of the cleaning solution to 8.0 millimeters of mercury at 20 degrees Celsius (68 degrees Fahrenheit). Minor Modification = Using the methods in §115.468(a)(1)-(3).	
PROEDC	40 CFR Part 63, Subpart F	63F-01	Applicable Chemicals = The chemical manufacturing process unit manufactures, as a primary product, one or more of the chemicals listed in 40 CFR § 63.100(b)(1)(i) or 40 CFR § 63.100(b)(1)(ii). Table 2 HAP = The chemical manufacturing process unit uses as a reactant or manufactures, as a product or co-product, one or more of the organic hazardous air pollutants in Table 2. Alternate Means of Emission Limitation = No alternative means of emission limitation has been approved by the EPA Administrator to	

Unit ID	Regulation	Index Number	Basis of Determination*	Changes and Exceptions to DSS**
			<p>achieve a reduction in organic HAP emission or no alternate has been requested.</p> <p>Heat Exchange System = No heat exchange system is utilized.</p>	
PROU5	40 CFR Part 63, Subpart F	63F-01	<p>Applicable Chemicals = The chemical manufacturing process unit manufactures, as a primary product, one or more of the chemicals listed in 40 CFR § 63.100(b)(1)(i) or 40 CFR § 63.100(b)(1)(ii).</p> <p>Table 2 HAP = The chemical manufacturing process unit uses as a reactant or manufactures, as a product or co-product, one or more of the organic hazardous air pollutants in Table 2.</p> <p>Alternate Means of Emission Limitation = No alternative means of emission limitation has been approved by the EPA Administrator to achieve a reduction in organic HAP emission or no alternate has been requested.</p> <p>Heat Exchange System = A heat exchange system is utilized.</p> <p>Cooling Water Pressure = The heat exchange system is not operated with the minimum pressure on the cooling water side at least 35 kilopascals greater than the maximum pressure on the process side.</p> <p>Intervening Cooling Fluid = There is no intervening cooling fluid containing less than 5 percent by weight of total HAPs listed in Table 4 of 40 CFR Part 63, Subpart F, between the process and cooling water.</p> <p>Table 4 HAP Content = The recirculating heat exchange system is not used exclusively to cool process fluids that contain less than 5 percent by weight of total HAPs listed in Table 4 of title 40 CFR Part 63, Subpart F.</p> <p>NPDES Permit = The once-through heat exchange system is not subject to NPDES permit with an allowable discharge limit of 1 part per million or less above influent concentration or 10 percent or less above influent concentration.</p> <p>Meets 40 CFR 63.104(a)(4)(i)-(iv) = The once-through heat exchange system is not subject to an NPDES permit that meets 40 CFR § 63.104(a)(4)(i) - (iv).</p> <p>Table 9 HAP Content = The once-through heat exchange system is not used exclusively to cool process fluids that contain less than 5 percent by weight of total HAPs listed in Table 9 of 40 CFR Part 63, Subpart G.</p> <p>Cooling Water Monitored = The cooling water is being monitored for the presence of one or more HAPs or other representative substances whose presence in cooling water indicates a leak.</p>	

* - The "unit attributes" or operating conditions that determine what requirements apply

** - Notes changes made to the automated results from the DSS, and a brief explanation why

NSR Versus Title V FOP

The state of Texas has two Air permitting programs, New Source Review (NSR) and Title V Federal Operating Permits. The two programs are substantially different both in intent and permit content.

NSR is a preconstruction permitting program authorized by the Texas Clean Air Act and Title I of the Federal Clean Air Act (FCAA). The processing of these permits is governed by 30 Texas Administrative Code (TAC) Chapter 116.111. The Title V Federal Operating Program is a federal program authorized under Title V of the FCAA that has been delegated to the state of Texas to administer and is governed by 30 TAC Chapter 122. The major differences between the two permitting programs are listed in the table below:

NSR Permit	Federal Operating Permit (FOP)
Issued Prior to new Construction or modification of an existing facility	For initial permit with application shield, can be issued after operation commences; significant revisions require approval prior to operation.
Authorizes air emissions	Codifies existing applicable requirements, does not authorize new emissions
Ensures issued permits are protective of the environment and human health by conducting a health effects review and that requirement for best available control technology (BACT) is implemented.	Applicable requirements listed in permit are used by the inspectors to ensure proper operation of the site as authorized. Ensures that adequate monitoring is in place to allow compliance determination with the FOP.
Up to two Public notices may be required. Opportunity for public comment and contested case hearings for some authorizations.	One public notice required. Opportunity for public comments. No contested case hearings.
Applies to all point source emissions in the state.	Applies to all major sources and some non-major sources identified by the EPA.
Applies to facilities: a portion of site or individual emission sources	One or multiple FOPs cover the entire site (consists of multiple facilities)
Permits include terms and conditions under which the applicant must construct and operate its various equipment and processes on a facility basis.	Permits include terms and conditions that specify the general operational requirements of the site; and include codification of all applicable requirements for emission units at the site.
Opportunity for EPA review for Federal Prevention of Significant Deterioration (PSD) and Nonattainment (NA) permits for major sources.	Opportunity for EPA review, affected states review, and a Public petition period for every FOP.
Permits have a table listing maximum emission limits for pollutants	Permit has an applicable requirements table and Periodic Monitoring (PM) / Compliance Assurance Monitoring (CAM) tables which document applicable monitoring requirements.
Permits can be altered or amended upon application by company. Permits must be issued before construction or modification of facilities can begin.	Permits can be revised through several revision processes, which provide for different levels of public notice and opportunity to comment. Changes that would be significant revisions require that a revised permit be issued before those changes can be operated.
NSR permits are issued independent of FOP requirements.	FOPs are independent of NSR permits, but contain a list of all NSR permits incorporated by reference

New Source Review Requirements

Below is a list of the New Source Review (NSR) permits for the permitted area. These NSR permits are incorporated by reference into the operating permit and are enforceable under it. These permits can be found in the main TCEQ file room, located on the first floor of Building E, 12100 Park 35 Circle, Austin, Texas. In addition, many of the permits are accessible online through the link provided below. The Public Education Program may be contacted at 1-800-687-4040 or the Air Permits Division (APD) may be contacted at 1-512-239-1250 for help with any question.

Additionally, the site contains emission units that are permitted by rule under the requirements of 30 TAC Chapter 106, Permits by Rule. Permit by Rule (PBR) registrations submitted by permittees are also available online through the link provided below. The following table specifies the PBRs that apply to the site.

The status of air permits, applications, and PBR registrations may be found by performing the appropriate search of the databases located at the following website:

www.tceq.texas.gov/permitting/air/nav/air_status_permits.html

Details on how to search the databases are available in the **Obtaining Permit Documents** section below.

New Source Review Authorization References

Title 30 TAC Chapter 116 Permits, Special Permits, and Other Authorizations (Other Than Permits by Rule, PSD Permits, or NA Permits) for the Application Area.	
Authorization No.: 19041	Issuance Date: 08/31/2021
Authorization No.: 48715	Issuance Date: 03/05/2018
Authorization No.: 83788	Issuance Date: 12/10/2021
Authorization No.: 93978	Issuance Date: 01/14/2022
Authorization No.: 120549	Issuance Date: 06/20/2023
Authorization No.: 150623	Issuance Date: 03/30/2018
Permits by Rule (30 TAC Chapter 106) for the Application Area	
Number: 106.183	Version No./Date: 09/04/2000
Number: 106.261	Version No./Date: 11/01/2003
Number: 106.262	Version No./Date: 11/01/2003
Number: 106.263	Version No./Date: 11/01/2001
Number: 106.264	Version No./Date: 09/04/2000
Number: 106.352	Version No./Date: 09/04/2000
Number: 106.472	Version No./Date: 09/04/2000
Number: 106.476	Version No./Date: 09/04/2000
Number: 106.478	Version No./Date: 09/04/2000
Number: 106.511	Version No./Date: 09/04/2000
Number: 106.532	Version No./Date: 09/04/2000

Permits by Rule

The TCEQ has interpreted the emission limits prescribed in 30 TAC §106.4(a) as both emission thresholds and default emission limits. The emission limits in 30 TAC §106.4(a) are all considered applicable to each facility as a threshold matter to ensure that the owner/operator qualifies for the PBR authorization. Those same emission limits are also the default emission limits if the specific PBR does not further limit emissions or there is no lower, certified emission limit claimed by the owner/operator.

This interpretation is consistent with how TCEQ has historically determined compliance with the emission limits prior to the addition of the “as applicable” language. The “as applicable” language was added in 2014 as part of changes to the sentence structure in a rulemaking that made other changes to address greenhouse gases and was not intended as a substantive rule change. This interpretation also provides for effective and practical enforcement of 30 TAC §106.4(a), since for the TCEQ to effectively enforce the emission limits in 30 TAC §106.4(a) as emission thresholds, all emission limits must apply. As provided by 30 TAC §106.4(a)(2) and (3), an owner/operator shall not claim a PBR authorization if the facility is subject to major New Source Review. The practical and legal effect of the language in 30 TAC § 106.4 is that

if a facility does not emit a pollutant, then the potential to emit for that particular pollutant is zero, and thus, the facility is not authorized to emit the pollutant pursuant to the PBR.

The permit holder is required to keep records for demonstrating compliance with PBRs in accordance with 30 TAC § 106.8 for the following categories:

- As stated in 30 TAC § 106.8(a), the permit holder is not required to keep records for de minimis sources as designated in 30 TAC § 116.119.
- As stated in 30 TAC § 106.8(b) for PBRs on the insignificant activities list, the permit holder is required to provide information that would demonstrate compliance with the general requirements of 30 TAC § 106.4.
- As stated in 30 TAC § 106.8(c) for all other PBRs, the permit holder must maintain sufficient records to demonstrate compliance with the general requirements specified in 30 TAC § 106.4 and to demonstrate compliance with the emission limits and any specific conditions of the PBR as applicable.

The application, or a previously submitted application, contains a PBR Supplemental Table. This table provides supplemental information for all PBR authorizations at the site or application area, including PBRs that are not listed on the OP-REQ1 form. PBRs that are not listed on the OP-REQ1 form authorize emission units that the TCEQ has determined are insignificant sources of emissions (IEUs). PBRs are enforceable through permit condition number 20. The EPA gives States broad discretion in prescribing monitoring, recordkeeping, and reporting for generally applicable requirements that cover insignificant emission units. (see EPA *White Paper Number 2 for Improved Implementation of the Part 70 Operating Permits Program*). Federal regulations specifically identify recordkeeping as an appropriate level of monitoring necessary to assure compliance with the requirements applicable to an emissions unit. Permitting authorities have the best sense of where it is appropriate to conclude that periodic monitoring is not necessary for IEUs, when state program rules already provide sufficient monitoring for these units.

In the case of IEUs in particular, the recordkeeping in 30 TAC §106.8 is sufficient because the units do not have the potential to violate emission limitations or other requirements under normal operating conditions. In particular, where the establishment of a regular program of monitoring would not significantly enhance the ability of the permit to assure compliance with the applicable requirement, the permitting authority can provide that the applicable requirement has monitoring sufficient to yield reliable data that is representative of the emission unit's compliance with the limitations. Therefore, for IEUs compliance with 30 TAC §106.8 is sufficient to meet federal monitoring requirements.

The PBR records may include, but are not limited to, production capacity and throughput, hours of operation, safety data sheets (SDS), chemical composition of raw materials, speciation of air contaminant data, engineering calculations, maintenance records, fugitive data, performance tests, capture/control device efficiencies, or parametric monitoring. The PBR records also satisfy the federal operating permit periodic monitoring requirements of 30 TAC § 122.142(c) as they are representative of the emission unit's compliance with 30 TAC Chapter 106.

Emission Units and Emission Points

In air permitting terminology, any source capable of generating emissions (for example, an engine or a sandblasting area) is called an Emission Unit. For purposes of Title V, emission units are specifically listed in the operating permit when they have applicable requirements other than New Source Review (NSR), or when they are listed in the permit shield table.

The actual physical location where the emissions enter the atmosphere (for example, an engine stack or a sand-blasting yard) is called an emission point. For New Source Review preconstruction permitting purposes, every emission unit has an associated emission point. Emission limits are listed in an NSR permit, associated with an emission point. This list of emission points and emission limits per pollutant is commonly referred to as the "Maximum Allowable Emission Rate Table", or "MAERT" for short. Specifically, the MAERT lists the Emission Point Number (EPN) that identifies the emission point, followed immediately by the Source Name, identifying the emission unit that is the source of those emissions on this table.

Thus, by reference, an emission unit in a Title V operating permit is linked by reference number to an NSR authorization, and its related emission point.

Monitoring Sufficiency

Federal and state rules, 40 CFR § 70.6(a)(3)(i)(B) and 30 TAC § 122.142(c) respectively, require that each federal operating permit include additional monitoring for applicable requirements that lack periodic or instrumental monitoring (which may include recordkeeping that serves as monitoring) that yields reliable data from a relevant time period that are representative of the emission unit's compliance with the applicable emission limitation or standard. Furthermore, the

federal operating permit must include compliance assurance monitoring (CAM) requirements for emission sources that meet the applicability criteria of 40 CFR Part 64 in accordance with 40 CFR § 70.6(a)(3)(i)(A) and 30 TAC § 122.604(b).

With the exception of any emission units listed in the Periodic Monitoring or CAM Summaries in the FOP, the TCEQ Executive Director has determined that the permit contains sufficient monitoring, testing, recordkeeping, and reporting requirements that assure compliance with the applicable requirements. If applicable, each emission unit that requires additional monitoring in the form of periodic monitoring or CAM is described in further detail under the Rationale for CAM/PM Methods Selected section following this paragraph.

Rationale for Compliance Assurance Monitoring (CAM)/ Periodic Monitoring Methods Selected

Periodic Monitoring:

The Federal Clean Air Act requires that each federal operating permit include monitoring sufficient to assure compliance with the terms and conditions of the permit. Most of the emission limits and standards applicable to emission units at Title V sources include adequate monitoring to show that the units meet the limits and standards. For those requirements that do not include monitoring, or where the monitoring is not sufficient to assure compliance, the federal operating permit must include such monitoring for the emission units affected. The following emission units are subject to periodic monitoring requirements because the emission units are subject to an emission limitation or standard for an air pollutant (or surrogate thereof) in an applicable requirement that does not already require monitoring, or the monitoring for the applicable requirement is not sufficient to assure compliance:

Unit/Group/Process Information	
ID No.: OC5DGRS	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Degreasing Processes	SOP Index No.: R5412-01
Pollutant: VOC	Main Standard: § 115.412(1)
Monitoring Information	
Indicator: Visual Inspection	
Minimum Frequency: Monthly	
Averaging Period: n/a	
Deviation Limit: A deviation is considered to be any monitoring data not in compliance with the applicable requirements of 30 TAC 115.412(a)(1)(A)-(F).	
Basis of monitoring: The monitoring option to cover cold cleaner or the open-top vapor cleaner was included in the EPA "Periodic Monitoring Technical Reference Document" (April 1999) to monitor VOC sources. In addition to covering the cleaner records of monthly inspections of equipment is an effective way to ensure that the system is operating in accordance with its design.	

Unit/Group/Process Information	
ID No.: OC5U5B01	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 117, Subchapter B	SOP Index No.: R7ICI-01
Pollutant: CO	Main Standard: § 117.310(c)(1)
Monitoring Information	
Indicator: Fuel gas usage	
Minimum Frequency: Hourly	
Averaging Period: N/A	
Deviation Limit: Any monitoring data above the hourly fuel usage (0.01 MMSCF/hr) shall be considered and reported as a deviation.	
Basis of monitoring: It is widely practiced and accepted to use performance tests, manufacturer's recommendations, engineering calculations and/or historical data to establish a correlation between fuel flow rates and emission rates. The fuel gas consumption is used in combination with the initial demonstration of compliance or AP-42 factors may be used to demonstrate compliance with an underlying emission limit or standard.	

Unit/Group/Process Information	
ID No.: OC5U5B02	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 117, Subchapter B	SOP Index No.: R7ICI-01
Pollutant: CO	Main Standard: § 117.310(c)(1)
Monitoring Information	
Indicator: Fuel gas usage	
Minimum Frequency: Hourly	
Averaging Period: n/a	
Deviation Limit: Any monitoring data above the hourly fuel usage (0.01 MMSCF/hr) shall be considered and reported as a deviation.	
Basis of monitoring: It is widely practiced and accepted to use performance tests, manufacturer's recommendations, engineering calculations and/or historical data to establish a correlation between fuel flow rates and emission rates. The fuel gas consumption is used in combination with the initial demonstration of compliance or AP-42 factors may be used to demonstrate compliance with an underlying emission limit or standard.	

Unit/Group/Process Information	
ID No.: OC5U5H201	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 117, Subchapter B	SOP Index No.: R7ICI-01
Pollutant: CO	Main Standard: § 117.310(c)(1)
Monitoring Information	
Indicator: Fuel gas usage	
Minimum Frequency: Hourly	
Averaging Period: N/A	
Deviation Limit: Any monitoring data above the hourly fuel gas usage (0.01 MMSCF/hr) shall be considered and reported as deviation	
Basis of monitoring: It is widely practiced and accepted to use performance tests, manufacturer's recommendations, engineering calculations and/or historical data to establish a correlation between fuel flow rates and emission rates. The fuel gas consumption is used in combination with the initial demonstration of compliance or AP-42 factors may be used to demonstrate compliance with an underlying emission limit or standard.	

Unit/Group/Process Information	
ID No.: OC5U5H202	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 117, Subchapter B	SOP Index No.: R7ICI-01
Pollutant: CO	Main Standard: § 117.310(c)(1)
Monitoring Information	
Indicator: Fuel gas usage	
Minimum Frequency: Hourly	
Averaging Period: N/A	
Deviation Limit: Any monitoring data above the hourly fuel gas usage (0.01 MMSCF/hr) shall be considered and reported as deviation	
Basis of monitoring: It is widely practiced and accepted to use performance tests, manufacturer's recommendations, engineering calculations and/or historical data to establish a correlation between fuel flow rates and emission rates. The fuel gas consumption is used in combination with the initial demonstration of compliance or AP-42 factors may be used to demonstrate compliance with an underlying emission limit or standard.	

Unit/Group/Process Information	
ID No.: OC5U5H203	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 117, Subchapter B	SOP Index No.: R7ICI-01
Pollutant: CO	Main Standard: § 117.310(c)(1)
Monitoring Information	
Indicator: Fuel gas usage	
Minimum Frequency: Hourly	
Averaging Period: N/A	
Deviation Limit: Any monitoring data above the hourly fuel gas usage (0.01 MMSCF/hr) shall be considered and reported as deviation	
Basis of monitoring: It is widely practiced and accepted to use performance tests, manufacturer's recommendations, engineering calculations and/or historical data to establish a correlation between fuel flow rates and emission rates. The fuel gas consumption is used in combination with the initial demonstration of compliance or AP-42 factors may be used to demonstrate compliance with an underlying emission limit or standard.	

Unit/Group/Process Information	
ID No.: OC5U5H204	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 117, Subchapter B	SOP Index No.: R7ICI-01
Pollutant: CO	Main Standard: § 117.310(c)(1)
Monitoring Information	
Indicator: Fuel gas usage	
Minimum Frequency: Hourly	
Averaging Period: N/A	
Deviation Limit: Any monitoring data above the hourly fuel gas usage (0.01 MMSCF/hr) shall be considered and reported as deviation	
Basis of monitoring: It is widely practiced and accepted to use performance tests, manufacturer's recommendations, engineering calculations and/or historical data to establish a correlation between fuel flow rates and emission rates. The fuel gas consumption is used in combination with the initial demonstration of compliance or AP-42 factors may be used to demonstrate compliance with an underlying emission limit or standard.	

Unit/Group/Process Information	
ID No.: OC5U5H206	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R1111-01
Pollutant: Opacity	Main Standard: § 111.111(a)(1)(B)
Monitoring Information	
Indicator: Fuel Type	
Minimum Frequency: Annually	
Averaging Period: n/a	
Deviation Limit: If an alternate fuel is fired, either alone or in combination with the specified gas, it shall be considered a deviation.	
Basis of monitoring: Industry has demonstrated through performance tests and historical data that opacity and particulate matter standards are consistently met when combustion units fire natural gas only.	

Unit/Group/Process Information	
ID No.: OC5U5H206	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 117, Subchapter B	SOP Index No.: R7ICI-01
Pollutant: CO	Main Standard: § 117.310(c)(1)
Monitoring Information	
Indicator: Fuel gas usage	
Minimum Frequency: Hourly	
Averaging Period: N/A	
Deviation Limit: Any monitoring data above the hourly fuel gas usage (0.01 MMSCF/hr) shall be considered and reported as deviation	
Basis of monitoring: It is widely practiced and accepted to use performance tests, manufacturer's recommendations, engineering calculations and/or historical data to establish a correlation between fuel flow rates and emission rates. The fuel gas consumption is used in combination with the initial demonstration of compliance or AP-42 factors may be used to demonstrate compliance with an underlying emission limit or standard.	

Unit/Group/Process Information	
ID No.: OC5U5H207	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R1111-01
Pollutant: Opacity	Main Standard: § 111.111(a)(1)(B)
Monitoring Information	
Indicator: Fuel Type	
Minimum Frequency: Annually	
Averaging Period: n/a	
Deviation Limit: If an alternate fuel is fired, either alone or in combination with the specified gas, it shall be considered a deviation.	
Basis of monitoring: Industry has demonstrated through performance tests and historical data that opacity and particulate matter standards are consistently met when combustion units fire natural gas only.	

Unit/Group/Process Information	
ID No.: OC5U5H207	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 117, Subchapter B	SOP Index No.: R7ICI-01
Pollutant: CO	Main Standard: § 117.310(c)(1)
Monitoring Information	
Indicator: Fuel gas usage	
Minimum Frequency: Hourly	
Averaging Period: N/A	
Deviation Limit: Any monitoring data above the hourly fuel gas usage (0.01 MMSCF/hr) shall be considered and reported as deviation	
Basis of monitoring: It is widely practiced and accepted to use performance tests, manufacturer's recommendations, engineering calculations and/or historical data to establish a correlation between fuel flow rates and emission rates. The fuel gas consumption is used in combination with the initial demonstration of compliance or AP-42 factors may be used to demonstrate compliance with an underlying emission limit or standard.	

Unit/Group/Process Information	
ID No.: OC5U5H208	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R1111-01
Pollutant: Opacity	Main Standard: § 111.111(a)(1)(B)
Monitoring Information	
Indicator: Fuel Type	
Minimum Frequency: Annually	
Averaging Period: n/a	
Deviation Limit: If an alternate fuel is fired, either alone or in combination with the specified gas, it shall be considered a deviation.	
Basis of monitoring: Industry has demonstrated through performance tests and historical data that opacity and particulate matter standards are consistently met when combustion units fire natural gas only.	

Unit/Group/Process Information	
ID No.: OC5U5H208	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 117, Subchapter B	SOP Index No.: R7ICI-01
Pollutant: CO	Main Standard: § 117.310(c)(1)
Monitoring Information	
Indicator: Fuel gas usage	
Minimum Frequency: Hourly	
Averaging Period: N/A	
Deviation Limit: Any monitoring data above the hourly fuel gas usage (0.01 MMSCF/hr) shall be considered and reported as deviation	
Basis of monitoring: It is widely practiced and accepted to use performance tests, manufacturer's recommendations, engineering calculations and/or historical data to establish a correlation between fuel flow rates and emission rates. The fuel gas consumption is used in combination with the initial demonstration of compliance or AP-42 factors may be used to demonstrate compliance with an underlying emission limit or standard.	

Unit/Group/Process Information	
ID No.: OC5U5H209	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R1111-01
Pollutant: Opacity	Main Standard: § 111.111(a)(1)(B)
Monitoring Information	
Indicator: Fuel Type	
Minimum Frequency: Annually	
Averaging Period: n/a	
Deviation Limit: If an alternate fuel is fired, either alone or in combination with the specified gas, it shall be considered a deviation.	
Basis of monitoring: Industry has demonstrated through performance tests and historical data that opacity and particulate matter standards are consistently met when combustion units fire natural gas only.	

Unit/Group/Process Information	
ID No.: OC5U5H209	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 117, Subchapter B	SOP Index No.: R7ICI-01
Pollutant: CO	Main Standard: § 117.310(c)(1)
Monitoring Information	
Indicator: Fuel gas usage	
Minimum Frequency: Hourly	
Averaging Period: N/A	
Deviation Limit: Any monitoring data above the hourly fuel gas usage (0.01 MMSCF/hr) shall be considered and reported as deviation	
Basis of monitoring: It is widely practiced and accepted to use performance tests, manufacturer's recommendations, engineering calculations and/or historical data to establish a correlation between fuel flow rates and emission rates. The fuel gas consumption is used in combination with the initial demonstration of compliance or AP-42 factors may be used to demonstrate compliance with an underlying emission limit or standard.	

Obtaining Permit Documents

The New Source Review Authorization References table in the FOP specifies all NSR authorizations that apply at the permit area covered by the FOP. Individual NSR permitting files are located in the TCEQ Central File Room (TCEQ Main Campus located at 12100 Park 35 Circle, Austin, Texas, 78753, Building E, Room 103). They can also be obtained electronically from TCEQ's Central File Room Online (<https://www.tceq.texas.gov/goto/cfr-online>). Guidance documents that describe how to search electronic records, including Permits by Rule (PBRs) or NSR permits incorporated by reference into an FOP, archived in the Central File Room server are available at https://www.tceq.texas.gov/permitting/air/nav/air_status_permits.html

All current PBRs are contained in Chapter 106 and can be viewed at the following website:

https://www.tceq.texas.gov/permitting/air/permitbyrule/air_pbr_index.html

Previous versions of 30 TAC Chapter 106 PBRs may be viewed at the following website:

www.tceq.texas.gov/permitting/air/permitbyrule/historical_rules/old106list/index106.html

Historical Standard Exemption lists may be viewed at the following website:

www.tceq.texas.gov/permitting/air/permitbyrule/historical_rules/oldselist/se_index.html

Additional information concerning PBRs is available on the TCEQ website:

https://www.tceq.texas.gov/permitting/air/nav/air_pbr.html

Available Unit Attribute Forms

- OP-UA1 - Miscellaneous and Generic Unit Attributes
- OP-UA2 - Stationary Reciprocating Internal Combustion Engine Attributes
- OP-UA3 - Storage Tank/Vessel Attributes
- OP-UA4 - Loading/Unloading Operations Attributes
- OP-UA5 - Process Heater/Furnace Attributes
- OP-UA6 - Boiler/Steam Generator/Steam Generating Unit Attributes
- OP-UA7 - Flare Attributes
- OP-UA10 - Gas Sweetening/Sulfur Recovery Unit Attributes
- OP-UA11 - Stationary Turbine Attributes

OP-UA12 - Fugitive Emission Unit Attributes
OP-UA13 - Industrial Process Cooling Tower Attributes
OP-UA14 - Water Separator Attributes
OP-UA15 - Emission Point/Stationary Vent/Distillation Operation/Process Vent Attributes
OP-UA16 - Solvent Degreasing Machine Attributes
OP-UA17 - Distillation Unit Attributes
OP-UA18 - Surface Coating Operations Attributes
OP-UA19 - Wastewater Unit Attributes
OP-UA20 - Asphalt Operations Attributes
OP-UA21 - Grain Elevator Attributes
OP-UA22 - Printing Attributes
OP-UA24 - Wool Fiberglass Insulation Manufacturing Plant Attributes
OP-UA25 - Synthetic Fiber Production Attributes
OP-UA26 - Electroplating and Anodizing Unit Attributes
OP-UA27 - Nitric Acid Manufacturing Attributes
OP-UA28 - Polymer Manufacturing Attributes
OP-UA29 - Glass Manufacturing Unit Attributes
OP-UA30 - Kraft, Soda, Sulfite, and Stand-Alone Semichemical Pulp Mill Attributes
OP-UA31 - Lead Smelting Attributes
OP-UA32 - Copper and Zinc Smelting/Brass and Bronze Production Attributes
OP-UA33 - Mineral Processing Plant Attributes
OP-UA34 - Pharmaceutical Manufacturing
OP-UA35 - Incinerator Attributes
OP-UA36 - Steel Plant Unit Attributes
OP-UA37 - Basic Oxygen Process Furnace Unit Attributes
OP-UA38 - Lead-Acid Battery Manufacturing Plant Attributes
OP-UA39 - Sterilization Source Attributes
OP-UA40 - Ferroalloy Production Facility Attributes
OP-UA41 - Dry Cleaning Facility Attributes
OP-UA42 - Phosphate Fertilizer Manufacturing Attributes
OP-UA43 - Sulfuric Acid Production Attributes
OP-UA44 - Municipal Solid Waste Landfill/Waste Disposal Site Attributes
OP-UA45 - Surface Impoundment Attributes
OP-UA46 - Epoxy Resins and Non-Nylon Polyamides Production Attributes
OP-UA47 - Ship Building and Ship Repair Unit Attributes
OP-UA48 - Air Oxidation Unit Process Attributes
OP-UA49 - Vacuum-Producing System Attributes
OP-UA50 - Fluid Catalytic Cracking Unit Catalyst Regenerator/Fuel Gas Combustion Device/Claus Sulfur Recovery Plant Attributes
OP-UA51 - Dryer/Kiln/Oven Attributes
OP-UA52 - Closed Vent Systems and Control Devices
OP-UA53 - Beryllium Processing Attributes
OP-UA54 - Mercury Chlor-Alkali Cell Attributes
OP-UA55 - Transfer System Attributes
OP-UA56 - Vinyl Chloride Process Attributes
OP-UA57 - Cleaning/Depainting Operation Attributes
OP-UA58 - Treatment Process Attributes
OP-UA59 - Coke By-Product Recovery Plant Attributes
OP-UA60 - Chemical Manufacturing Process Unit Attributes
OP-UA61 - Pulp, Paper, or Paperboard Producing Process Attributes
OP-UA62 - Glycol Dehydration Unit Attributes
OP-UA63 - Vegetable Oil Production Attributes
OP-UA64 - Coal Preparation Plant Attributes